

## **Revised GTR for OPGW manufacturers**

### **1.0 TECHNICAL EXPERIENCE**

- (a) OPGW manufacturer should be a “Class-I Local Supplier” as per latest DPIIT, MoP and DoT notification.
- (b) (i) OPGW manufacturer must have manufactured, type tested (as per IEC or equivalent standard) and supplied at least 100 Kms of OPGW during last seven (7) years and the same must be in satisfactory operation# for at least one (01) year on 66kV or above transmission line(s), as on the originally scheduled last date of bid submission (soft copy).

**OR**

- (ii) OPGW manufacturer must have manufactured, type tested (as per IEC or equivalent standard) and supplied at least 100 Kms of OPGW as on the originally scheduled last date of bid submission . Further, extended warranty of one (1) year over and above the warranty period specified for OPGW shall be submitted.
- (c) OPGW manufacturer established as Subsidiary/JVC/Group company who has manufactured, type tested (as per IEC or equivalent standard) and supplied OPGW and meets the requirement at (a) but not (b)(i) above, shall also be considered, provided its Parent/Principal company meets the requirement at (b)(i) above. Further the following shall also be submitted by OPGW manufacturer:
- i) Performance guarantee for an amount of 10% of the cost of OPGW cable.
  - ii) Valid agreement (between Parent/ Principal and OPGW manufacturer) for technology transfer / license to design, manufacture, test and supply OPGW in India.

Note 1: #Satisfactory operation – means Certificate issued by the Employer certifying the operation without any adverse remark.

#### **For Live Line Installation (if applicable)**

Agency must have installed at least 100 Kms of OPGW cable in live-line condition on 66 kV or higher voltage transmission line(s), as on the originally scheduled last date of bid submission