

Amendment No-V dated 30/10/2025 to the Bidding Documents for 400kV Transformer Package 4TR-15-BULK (AM) for 12 x 500 MVA 400/220/33kV 3-Ph Transformers, 6x 315MVA 400/220/33kV 3-Ph Transformer & 1x315MVA 400/132/33kV 3-Ph Transformers under "Bulk Procurement of 765kV & 400kV class Transformers & Reactors of various Capacities (Lot-6). Spec No. CC/NT/W-TR/DOM/A00/25/11539.

Sl. No.	Clause Ref. No.	Existing provision	Amended as
1.	Section Transformer Rev-13 Annexure-A 3.0 Clause 3.25	Maximum Permissible Losses of Transformers (315MVA) i) Max. No Load Loss at rated voltage and frequency - 75kW ii) Max. Load Loss between HV & IV at rated current and frequency and at 75 C - 440kW iii) Max. I ² R Loss at rated current at 75 C- 330kW iv) Max. Auxiliary Loss at rated voltage and frequency - 10kW	Maximum Permissible Losses of Transformers (315MVA) i) Max. No Load Loss at rated voltage and frequency - 100kW ii) Max. Load Loss between HV & IV at rated current and frequency and at 75 C - 470kW iii) Max. I ² R Loss at rated current at 75 C - 365kW iv) Max. Auxiliary Loss at rated voltage and frequency - 11kW