

Clarification No-01 Dated 30.10.2025 to Bidding Document for 400kV Transformer Package 4TR-15-BULK (AM) for 12 x 500 MVA 400/220/33kV 3-Ph Transformers, 6x 315MVA 400/220/33kV 3-Ph Transformer & 1x315MVA 400/132/33kV 3-Ph Transformers under "Bulk Procurement of 765kV & 400kV class Transformers & Reactors of various Capacities (Lot-6).;

Sl. No.	Provision in Bidding Document	Bidder's Query	POWERGRID's Reply
1.	Section Transformer Rev-13; Clause 3.14.1 & 5.4 BPS S.No. 5	<p>BPS Schedule 1 > S.No. 5 > 315 MVA, 400/132/33 kV, 3-Phase AutoTransformer</p> <p>Bidder do not have dynamic short circuit test report on similar rating. Bidder has Dynamic short circuit test report of 315 MVA, 400/220 kV ICT, manufactured from T1 plant Mumbai (permanently non-operational) and 500 MVA, 400/220 kV ICT test is under process. Bidder is unable to prove short circuit similarity due to change of Impedance Values for IV-LV Pair, Absorbed Power Criteria is beyond allowable range for IV-LV Pair.</p> <p>Hence, Bidder is not qualifying as per qualification criteria.</p> <p>Note: As per PGCIL Specification Rev 13, Dynamic Short Circuit Test (DSC) considered as a Type Test. Bidder shall not perform any short circuit Test on 315 MVA, 400/132/33 kV, 3-Phase AutoTransformer. If required, we can only submit short circuit calculation during the detailed engineering.</p> <p>We request PGCIL to kindly waive off the Dynamic Short Circuit requirement on 315 MVA, 400/132/33 kV, 3-Phase AutoTransformer and allow us to submit our most competitive bid.</p>	Bidder shall quote meeting the requirement of bidding documents
2.	Section Transformer Rev-13; Annexure-A 3.0 Clause 3.25	<p>As discussed, we would like to highlight a critical point regarding the 315 MVA, 400/132/33 kV Auto-transformers in subject tender spec.</p> <p>Unfeasible Loss Parameters: The specified loss values (No Load Losses: 72 kW, Load Losses: 400 kW, Auxiliary Losses: 10 kW) are not technically achievable/viable with current manufacturing capabilities for a transformer of this rating and voltage class. These values are significantly lower than industry norms.</p> <p>Moreover, Bidder, along with other leading OEMs, had earlier initiated discussions with the CEA to amend the standardized loss values for the 315 MVA, 400/132/33 kV Auto Transformer. The proposed and technically feasible loss values are:</p>	Please refer Amendment No-V to the bidding documents

Clarification No-01 Dated 30.10.2025 to Bidding Document for 400kV Transformer Package 4TR-15-BULK (AM) for 12 x 500 MVA 400/220/33kV 3-Ph Transformers, 6x 315MVA 400/220/33kV 3-Ph Transformer & 1x315MVA 400/132/33kV 3-Ph Transformers under "Bulk Procurement of 765kV & 400kV class Transformers & Reactors of various Capacities (Lot-6).;

Sl. No.	Provision in Bidding Document	Bidder's Query	POWERGRID's Reply
		<ul style="list-style-type: none"> · No Load Losses (NLL): 100 kW · Load Losses (LL): 470 kW (I²R component: 360 kW) · Auxiliary Losses (AL): 11 kW <p>To ensure compliance and a viable solution, we kindly request you to engage with CEA to consider revising the transformer loss values, which are under discussion with the CEA and supported by multiple OEMs.</p>	