



Bid Number: GEM/2025/B/6021431

Dated: 28-03-2025

Bid Corrigendum

GEM/2025/B/6021431-C3

Following terms and conditions supersede all existing "Buyer added Bid Specific Terms and conditions" given in the bid document or any previous corrigendum. Prospective bidders are advised to bid as per following Terms and Conditions:

Buyer Added Bid Specific Additional Terms and Conditions

- 1. Bidder shall submit the following documents along with their bid for Vendor Code Creation:
 - a. Copy of PAN Card.
 - b. Copy of GSTIN.
 - c. Copy of Cancelled Cheque.
 - d. Copy of EFT Mandate duly certified by Bank.
- 2. Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.
- 3. Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods
- Bidders can also submit the EMD with Account Payee Demand Draft in favour of Power Grid Corporation of India Limited payable at

Lucknow

Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

 Bidders can also submit the EMD with Banker's Cheque in favour of Power Grid Corporation of India Limited payable at Lucknow

Lucknov


Bidder has to upload scanned copy / proof of the BC along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

 Successful Bidder can submit the Performance Security in the form of Account Payee Demand Draft also (besides PBG which is allowed as per GeM GTC). DD should be made in favour of Power Grid Corporation of India Limited payable at

Lucknow

. After award of contract, Successful Bidder can upload scanned copy of the DD in place of PBG and has to ensure delivery of hard copy to the original DD to the Buyer within 15 days of award of contract.

7. Buyer Added text based ATC clauses



""Supply and Retrofitment of VRLA Battery Banks at various Substations in NR-III and Odisha Regions of PO WERGRID". (Specification No.: NCN0103)

Pre-bid Meeting:

Pre-Bid Meeting shall be conducted on 19.03.2025 at 11:00 am (In Hy brid Mode). Request for providing link for participation in online Pre-Bid Meeting shall be sent by bidder through e-mail at cpc@powergrid.in

Venue for Physical Meeting:

Centralized Procurement Cell,

3rd Floor, Plot No. – 2A/INS 02, Avadh Vihar Yojna, Amar Shaheed Path .

Near Medanta Hospital, Lucknow- 226002 (UP)

CORRIGENDUM-I

GEM BID REF. NO. GEM/2025/B/6021431 Dated: 12-03-2025.

Reply to clarifications raised by bidder(s) is as tabulated below:

Clause No.	Clarification sought	POWERGRID's Reply
General	BOQ Item No20-Spares cells 2V/40 0AH VRLA- As Battery is being procured for Item No.20 as 48V 1500AH hence, Spare cells rating should be same as 2V 1500AH. Pls amend the battery capacity in Item No20	The Spare cell rating for BoQ it em 20 (GeM Consignee: buyera ngul2) shall be read as 2V/150 OAH in place of 2V/400AH.
General	Please ensure for issuing SAP PO & TOC within 7 days after receipt of G eM PO & Completion of works at Sit es respectively.	SAP PO will be issued within 7 d ays from the issuing date of Ge M PO. TOC provisions shall be a s per tender document.
General	In BoQ detailed document, some of the line items are referring to IEC st andard 62259.	For subject package, wherever I EC 62259 has been mentioned, the same shall be read as IEC 6 0896 - 21 & 22 in place of IEC 62259

This corrigendum shall form an integral part of the bid documents and shall be read in conjunction with t he same.

8. Buyer uploaded ATC document Click here to view the file.

Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

- 1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
- 2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
- 3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
- 4. Creating BoQ bid for single item.
- 5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
- 6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
- 7. Floating / creation of work contracts as Custom Bids in Services.
- 8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for <u>attached categories</u>, trials are allowed as per approved procurement policy of the buyer nodal Ministries)
- 9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
- 10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
- 11. Creating bid for items from irrelevant categories.
- 12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
- 13. Reference of conditions published on any external site or reference to external documents/clauses.
- 14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

This Bid is also governed by the General Terms and Conditions

^{*}This document shall overwrite all previous versions of Bid Specific Additional Terms and Conditions.