

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	28-07-2026 11:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	28-07-2026 11:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	180 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Power
विभाग का नाम/Department Name	Power Grid Corporation Of India Limited
संगठन का नाम/Organisation Name	Power Grid Corporation Of India Limited
कार्यालय का नाम/Office Name	Corporate Office Gurgaon
शिकायत निवारण के संपर्क विवरण/ Contact details of Grievance redressal	HOD Email id :saroj.mishra@powergrid.in Buyer Email id: buycon32.pgCIL.up@gembuyer.in
कुल मात्रा/Total Quantity	41
वस्तु श्रेणी /Item Category	Supply of 145 kV RIP RIS Bushings Draw lead Draw Rod type with metal part and gasket for Altitude MSL-1600 meter and above , Supply of 145 kV RIP RIS Bushings Draw lead Draw Rod type with metal part and gasket Draw lead Draw Rod type with metal part and gasket , Supply of 145kV 1250A Draw lead rod type RIP RIS Bushing as per Technical Specification L2-600 L6-100 , Supply of 145kV 1250A Solid Stem type RIP RIS Bushing with Metal Parts and Gasket L2-800 L6-300 , Supply of 145kV 1250A Draw lead rod type RIP RIS Bushing as per Technical Specification
GeMARPTS में खोजी गई स्ट्रिंग्स / Searched Strings used in GeMARPTS	RIP/RIS bushing
GeMARPTS में खोजा गया परिणाम / Searched Result generated in GeMARPTS	Carbon Bush, CHLORINATED POLYVINYL CHLORIDE (CPVC) FITTINGS FOR POTABLE HOT AND COLD WATER DISTRIBUTION SUPPLIES Conforming to IS 17546, Seam ripper, LCR Meter, Risperidone Tablets, Bush Bearing, Risperidone Injection, User and Entity Behavior Analytics (UEBA), Archery Recurve Bow - Riser and Limbs, Business Intelligence and Data Analysis Software (V2)
अधिसूचना के लिए चयनित प्रासंगिक श्रेणियाँ / Relevant Categories selected for notification	<ul style="list-style-type: none"> • Business Intelligence and Data Analysis Software (V2) • Bush Bearing • Carbon Bush
बीओक्यू शीर्षक /BOQ Title	Supply of 145kV RIP RIS bushing

बिड विवरण/Bid Details	
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Relaxation for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Certificate (Requested in ATC),OEM Authorization Certificate,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Additional Doc 3 (Requested in ATC),Additional Doc 4 (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	No
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या / Minimum number of bids required to disable automatic bid extension	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	3
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/RA Qualification Rule	50% Lowest Priced Technically Qualified Bidders
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	Supply of 145kV 1250A Draw lead rod type RIP RIS Bushing as per Technical Specification
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	3 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Payment Timelines	Payments shall be made to the Seller within 30 days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)

बिड विवरण/Bid Details

मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	871000

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)	5.00
ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).	26

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने है। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b).ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

(c).ईएमडी और संपादन जमानत राशि लाभार्थी के पक्ष में होनी चाहिए। / Earnest Money Deposit (EMD) shall also be accepted by the buyer in the form of a surety bond.

लाभार्थी /Beneficiary :

POWERGRID

Power Grid Corporation of India Limited, Central Procurement Cell, Plot No. - 2A/INS 02, Avadh Vihar Yojna, Amar Shaheed Path, Near Medanta Hospital, Lucknow- 226002 (UP)
(Power Grid Corporation Of India Limited)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई के लिए आरक्षित / Reserved for Make In India products

एमआईआई के लिए आरक्षित / Reserved for Make In India products	Yes
---	-----

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
---	-----

सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं/सेवा प्रदाता को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% / Purchase Preference to MSE OEMs/ Service Provider available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माता/सेवा प्रदाता को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Percentage of Bid quantity/amount for MSE OEMs/ Service Provider Purchase preference	25

ट्रेड्स भुगतान संबंधी विवरण/TReDS Payment Details

This Bid provides for Trade Receivables Discounting System (TReDS) as Preferred mode of payment. For MSME sellers, payments may be processed through a TReDS exchange in which the Buyer is registered, subject to applicable policy and regulatory guidelines. Accordingly, sellers intending to avail payment through TReDS are required to be registered with at least one TReDS exchange in which the buyer is registered.

1. Bid reserved for Make In India products: : Procurement under this bid is reserved for purchase from Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. However, eligible micro and small enterprises will be allowed to participate. The minimum local content to qualify as a class 1 local supplier is denoted in the bid document. All bidders must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which the bid is liable to be rejected. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020 . In case Buyer has selected Purchase preference to Micro and Small Enterprises clause in the bid, the same will get precedence over this clause.

2. **Purchase preference to Micro and Small Enterprises (MSEs):** Purchase preference will be given to MSEs having valid Udyam Certificate and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service, and Buyer will decide eligibility for purchase preference based on documentary evidence submitted in case of product bids, whereas in case of services the eligibility is automatically validated. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

3. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

4. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will

be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

Pre Bid Detail(s)

मूल्य भिन्नता खंड दस्तावेज/Pre-Bid Date and Time	प्री-बिड स्थान/Pre-Bid Venue
14-07-2026 11:00:00	Pre-Bid Meeting shall be conducted as per scheduled date indicated in GeM Bid (In Online Mode). Request for providing link for participation in online Pre-Bid Meeting shall be sent by bidder through e-mail at cpc@powergrid.in

Supply Of 145 KV RIP RIS Bushings Draw Lead Draw Rod Type With Metal Part And Gasket For Altitude MSL-1600 Meter And Above

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Mouzim Mushtaq	192102,POWER GRID CORPORATION OF INDIA LTD, 400/220 kV Sub Station , New Wanpoh , Village Damjan, National Highway 1A, Tehsil Qazigund , Distt. Anantnag , J&K - 192102	1	365

Supply Of 145 KV RIP RIS Bushings Draw Lead Draw Rod Type With Metal Part And Gasket For Altitude MSL-1600 Meter And Above

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Syed Uzairul Muazam	192121,POWER GRID CORPORATION OF INDIA LIMITED, 400/220 kV Sub Station , Village Wagoora , Tehsil B.K.Pora , Distt. Budgam, J&K - 192121	1	365

Supply Of 145 KV RIP RIS Bushings Draw Lead Draw Rod Type With Metal Part And Gasket Draw Lead Draw Rod Type With Metal Part And Gasket

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Vishal	176310,Power Grid Corporation of India Ltd, 400/220 KV GIS Substation, V&PO - Rajera Distt. Chamba, Himachal Pradesh-176310	1	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification L2-600 L6-100

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rakesh Surendra Vhatkar	410507,Powergrid Corporation of India Limited 400/220 KV Substation, Plot No A 14/15, Talegaon MIDC, Village-Nav Lakh Umbre	1	365

Supply Of 145kV 1250A Solid Stem Type RIP RIS Bushing With Metal Parts And Gasket L2-800 L6-300

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Narsingh Kumar Raj	496111,Powergrid corporation of India Ltd, Near Tamnar, Village:Bhendra, Raigarh Road,Gharghoda, (Opp. Gharghoda Bypass Point), Dist. Raigarh, Chhattisgarh-496111 "	1	365

Supply Of 145kV 1250A Solid Stem Type RIP RIS Bushing With Metal Parts And Gasket L2-800 L6-300

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	SURYA KUMAR LEKKALA	490042,POWERGRID CORPORATION OF INDIA LIMITED, 400/220 KV Sub- Station, G.E Road, P.O. Kumhari, Distt: Durg, Chhatisgarh-490042	1	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Bhumireddy Srilakshmi Prasanna	560082,POWERGRID CORPORATION OF INDIA LIMITED, 400 kV BANGALORE SUB STATION, 26th KM Kanakapura Road, Somanahalli, BANGALORE, Karnataka- 560082	4	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Gnanaprakasam Balakrishnan	636502,Powergrid Corporation of India limited, 400KV SUBSTATION, K.R.THOPPUR, STEELPLANT-THARAMANGALAM ROAD, KONAKAPADI (POST) SALEM, TAMILNADU - 636502	7	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Jeethesh S	642203,POWERGRID CORPORATION OF INDIA LIMITED, 400KV substation, Kaniyur (Via), Myvadi(Post), Udumalpet, Tirupur Dist, Tamil Nadu - 642203	4	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
-------------------	---	-------------	------------------	---------------------------------

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	M J Paulose	680654,POWERGRID CORPORATION OF INDIA LIMITED, 400 KV SUBSTATION, VELLANIKARA POST, THRISSUR, Kerala-680654	1	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Santhosh K John	602105,POWERGRID CORPORATION OF INDIA LIMITED, 400KV SUBSTATION, PENNALUR, SRIPERUMBUDUR, Kancheepuram Dist, TAMILNADU-602105	3	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Srinivasan R	625514,Powergrid Corporation of India limited, Madurai 400/230KV Substation P.O. Kinnimangalam Via Chekkanurani Distt. Madurai, Tamilnadu-625514	3	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aruljothi Rathinam	620012,POWERGRID CORPORATION OF INDIA LIMITED, 400/230KV TRICHY SUBSTATION, FATHIMA NAGAR PO, ALUNDUR TRICHY TAMILNADU-620012	2	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Lingari Venkata Surendra Reddy	563101,Powergrid Corporation of India limited, Kolar 2500 MW HVDC Terminal Station Kolar- Chintamani Road Arahalli Post, Kolar, Karnataka-563101	2	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Aneesh P V	695316,Power Grid Corporation of India Ltd. 400 kV Substation Pallipuram Trivandrum	1	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rohan Pravin Kulkarni	573220,POWERGRID CORPORATION OF INDIA LIMITED, 400/220kV Substation, NH48, BM Road,Gadenahally cross, Doddagenegire (Post), Near Shantigrama, Hassan, Karnataka-573220	1	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
-------------------	---	-------------	------------------	---------------------------------

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Navya. S	683565,POWERGRID CORPORATION OF INDIA LIMITED, 400/220 kV KOCHI SUBSTATION, PALLIKKARA, KUMARAPURAM PO, KOCHI, Kerala-683565	2	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	S Akaash	678622,POWERGRID CORPORATION OF INDIA LIMITED, 400/220 kV Substation Cherottuveli village, Vengodi post, Elappully, Para, Palakkad, Kerala -678622	1	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	M Balu	636803,POWERGRID CORPORATION OF INDIA LIMITED, 765/400 KV SS, 15th Km, Dharmapuri-Hogenekal SH, Indur, Dharmapuri District, Tamil Nadu -636803	2	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Avala Srinu	628902,POWERGRID CORPORATION OF INDIA LIMITED, 765/400 kV Substation Ettayapuram, Tuticorin District, Tamil Nadu-628902	1	365

Supply Of 145kV 1250A Draw Lead Rod Type RIP RIS Bushing As Per Technical Specification

(Minimum 50% Local Content required for qualifying as Class 1 Local Supplier)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Shitha Kolangareth	673639,POWERGRID CORPORATION OF INDIA LIMITED, 400kV Kozhikode substation, Areekode, Chemrakatoor PO, Malappuram Dt., Kerala-673639	1	365

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

Buyer Organization specific Integrity Pact shall have to be complied by all bidders. Bidders shall have to upload scanned copy of signed integrity pact as per Buyer organizations policy along with bid. [Click here to view the file](#)

2. Generic

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- Copy of PAN Card.
- Copy of GSTIN.
- Copy of Cancelled Cheque.
- Copy of EFT Mandate duly certified by Bank.

3. Generic

Supplier shall ensure that the Invoice is raised in the name of Consignee with GSTIN of Consignee only.

4. Generic

Without prejudice to Buyer's right to price adjustment by way of discount or any other right or remedy available to Buyer, Buyer may terminate the Contract or any part thereof by a written notice to the Seller, if:

- The Seller fails to comply with any material term of the Contract.
- The Seller informs Buyer of its inability to deliver the Material(s) or any part thereof within the stipulated Delivery Period or such inability otherwise becomes apparent.
- The Seller fails to deliver the Material(s) or any part thereof within the stipulated Delivery Period

and/or to replace/rectify any rejected or defective Material(s) promptly.

iv) The Seller becomes bankrupt or goes into liquidation.

v) The Seller makes a general assignment for the benefit of creditors.

vi) A receiver is appointed for any substantial property owned by the Seller.

vii) The Seller has misrepresented to Buyer, acting on which misrepresentation Buyer has placed the Purchase Order on the Seller.

5. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Only supply of Goods

6. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

7. **Forms of EMD and PBG**

Bidders can also submit the EMD with Account Payee Demand Draft in favour of

Power Grid Corporation of India Limited
payable at
Lucknow

.
Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

8. **Forms of EMD and PBG**

Bidders can also submit the EMD with Banker's Cheque in favour of

Power Grid Corporation of India Limited
payable at
Lucknow

.
Bidder has to upload scanned copy / proof of the BC along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

9. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

“Supply of 145 kV Draw Rod/Draw Lead and Solid Stem RIP/RIS bushing for various substation of WR-I, NR-II and SR-II of POWERGRID”

[Specification. No.: NCN0341](#)

10. **Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/Disclaimer

The Additional Terms and Conditions (ATC) have been incorporated by the Buyer after approval of their Competent Authority. The Buyer, is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any restriction arising in the bidding process due to these ATCs and including the modification of technical specifications and / or terms and conditions governing the bid. All representations / grievances pertaining to the ATC clauses shall be raised with the buyer organization directly and not with GeM. If any of the clause(s) is/are incorporated by the Buyer regarding the following, the bid &

resultant contract shall be treated as null & void. Further, GeM reserves the right, at its sole discretion, to cancel the bid forthwith, without issuance of any prior notice or intimation :-

1. Publishing Custom / BOQ bids for items for which regular GeM categories are available (unless such Custom / BOQ item is bunched with the major regular product Category Item).
2. Mandating procurement of / from specific Brand / Make / Model / Manufacturer / Dealer except in case of Single Bid / Proprietary Article Certificate (PAC) Buying.
3. Inclusion of disqualification criteria related to suspension of seller / service provider, where such suspension period has already expired.
4. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
5. Publishing bids on GeM for procurement of works.
6. Procurement of Goods by creating a Service bid on GeM & vice-versa.
7. Seeking sample with bid or approval of samples during bid evaluation process. However, trial / sample, as the case may be, shall be permitted in cases where trial / sample are allowed as per approved and published procurement policy of the Buyers' controlling Ministry / Department / State / Public Sector Enterprises Headquarters. If there is any violation of trial / sample clause with regard to approved policy of the Buyers' Ministry / Department / State / Public Sector Enterprises Headquarters, then this is to be determined and redressed by the concerned Buyer Organisation only.
8. Seeking experience from specific organization / department / institute only or from foreign / export experience.
9. Creating bid for items from incorrect categories.
10. Reference of conditions published on any external site or reference to external documents/clauses.
11. Asking for any Tender fee / Bid Participation fee, as the case may be.
12. Buyer added ATC Clauses which are in contravention of clauses defined in bid detail section, including specifications, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by the applicable GeM GTC.
13. Any ATC clause in contravention with GeM GTC Clause 4 (xiii) (h) will be invalid. In case of multiple L1 bidders against a service bid, the buyer shall place the Contract by selection of a bidder amongst the L-1 bidders through a Random Algorithm executed by GeM system.
14. In a category based bid, adding additional items, through buyer added, additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogues or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-

compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

This Bid is governed by the General Terms and Conditions, conditions stipulated in Bid and Service Level Agreement specific to the Service, as the case may be, as provided in the Marketplace.

However, in case of Service, if any condition specified in General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement specific to said Service, then it will over-ride the conditions in the General Terms and Conditions.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---