

Ref: SRTS-II/C&M/WC-4218/2025
Date:26.05.2025
Package Name: Construction of 220kV Terminal Bay at 400kV Hiriyr Substation for KPTCL by POWERGRID
RFX No: 5002004216
Sub: Clarification and Amendment- II to Bidding Document -Reg

Due to change in requirement, the Bill of Quantity has been amended. Further the clarification to the queries of the bidder are provided as per the details below.

Sl. No	Bidder Query	Clarification by POWERGRID
1	As per BDS and price schedule, new Control Relay Protection panel has to be supplied and installed at existing SPR. During the visit, we have observed that in your existing control room there is no space available for installing the new CRP & SAS panels. However Price Schedule No. 1, item C, sub item 4, calls for Augmentation of existing Control Panel. Please note since there is no existing control panel, this augmentation is not applicable and request to delete this item from price schedule (both schedule 1 & 3) and send us revised schedule of prices.	Agency is requested to quote as per BOQ/section projects/tender documents.
2	Further during the telecon with your Hiriyr substation and your control room in-charge today, we were informed that control of new proposed bay 218 will be from the control room and that we also need to provide computers and necessary software/ hardware for the same. Please note that as per BDS and technical specifications, new CRP to be provided and installed at existing SPR and there is no requirement of computers, softwares/ hardwares specified in the technical specifications/BDS and PriceSchedule.	Agency is requested to quote as per BOQ/section project/tender documents.

Sl. No	Bidder Query	Clarification by POWERGRID
3	As your Ref: SRTS-II/C&M/WC-4218/2025 dated 06.05.2025. Amendment -1 Price schedule Rev1. The new SPR control room has been removed from the scope. Therefore Part-B- Vendor assessed Quantities Item No. D Fire protection system – will not be applicable.	Item--Part-B- Vendor assessed Quantities Item No. D -- Fire Detection and Alarm System for Switchyard Panel Room of 6 m length <u>stands deleted</u> along with corresponding supply/service /F&I items. In view of the above the amended price schedule is attached as Price_schedule_Rev2.

All the bidders shall take a note of the above clarification and amendment in price schedule and submit their bids as per the amended document.

Save and except above, all other terms and conditions of the bidding document remains unchanged.

