

**स्पीड पोस्ट/फैक्स**

सन्दर्भ संख्या/Ref: ODP/BB/C&M-3575/OT-24/RFx No. 5002003243/23-24/Clar-I & Extn-IV/  
दिनांक/Date: 22.04.2024

प्रति (On Individual Basis)

.....  
.....

विषय/SUB: " ओपीटीसीएल को कंसल्टेंसी सेवाओं के तहत पावरग्रिड द्वारा ओपीटीसीएल स्टैम्स (स्टेट ट्रांसमिशन एसेट मैनेजमेंट सिस्टम) परियोजना के लिए एक नियंत्रण केंद्र भवन का निर्माण || Construction of a Control Centre Building for OPTCL STAMS (State Transmission Asset Management System) Project by POWERGRID under Consultancy Services to OPTCL"- Clarification-I & Sale Extension -IV.

निविदा संदर्भ सं./NIT Ref. No. ODP/BB/C&M-3575/OT-24/RFx No. 5002003243/23-24 dated 23.01.2024

महोदय/Dear Sir,

- 1.0 इसका सन्दर्भ उपर्युक्त विषय से है। /This has reference to above.
- 2.0 Some of the bidders have sought some queries regarding Technical Specifications. In this regard please find the clarifications attached herewith as Annexure\_I.
- 3.0 In view of above, sale period of the subject package has been extended upto 17.00 Hrs on 03.05.2024.
- 4.0 Accordingly, the tenders shall be accepted upto 15.00 Hrs on 08.05.2024 and first envelope of tender shall be opened at 15.30 Hrs on 08.05.2024.
- 5.0 यह आपके जानकारी हेतु तथा बोलियां प्रस्तुत करने के लिए है।/This is for information and submission of bids accordingly.  
सधन्यवाद |

भवदीय/Yours' faithfully,  
For and on behalf of POWERGRID

 Recoverable Signature

X Yogesh

Signed by: 25bacdff-735c-48f6-a43b-9f364fb0f7cf

(योगेश कुशवाहा / Yogesh Kushwaha)  
उप प्रबंधक (सं सा)/Dy. Manager (C&M)

साइटऑफिस: प्लॉट नं 4, यूनिट-४१, निलाद्री विहार, चन्द्रशेखरपुर, भुवनेश्वर-751021 दूरभाष: + 91-0674-2720794

Site Office: Plot No. 4, Unit-41, Niladri Vihar, Chandrashekharpur, Bhubaneswar-751021 Tel: + 91-0674-2720794

केन्द्रीय कार्यालय: "सौदामिनी", प्लॉट नंबर 2, सेक्टर -29, गुरुग्राम -122001, (हरियाणा) दूरभाष: 0124-2571700-719

Corporate Office: "Saudamini", Plot No. 2, Sector-29, Gurugram-122001, (Haryana) Tel.: 0124-2571700-719

पंजीकृत कार्यालय: बी -9, कुतब इंस्टीट्यूशनल एरिया, कटवारिया सराय, नई दिल्ली -110 016. दूरभाष: 011-26560112, 26560121, 26564812, 26564892, CIN: L40101DL1989GOI038121

Registered Office: B-9, Qutab Institutional Area, Katwaria Sarai, New Delhi-110 016. Tel: 011-26560112, 26560121, 26564812, 26564892, CIN : L40101DL1989GOI038121

Website: www.powergrid.in

**Annexure-I**

**Clarification-I to Open Tender Enquiry for "Construction of a Control Centre Building for OPTCL STAMS (State Transmission Asset Management System)  
Project by POWERGRID under Consultancy Services to OPTCL"  
NIT Ref. No. ODP/BB/C&M-3575/OT-24/RfX No. 5002003243/23-24 dated 23.01.2024**

<b>Sl. No.</b>	<b>Query raised by Bidder (s)</b>	<b>POWERGRID's Clarification</b>
1	Electrical LT Panels - No Incoming /outgoing given in the BOQ and mentioned "design supply erection and testing commissioning of LT panels"	<b>LT Panel Incoming-433 V as mentioned in BOQ</b>
2	If the design is within the scope of the contractor, then we require raw data like Load detail of the building, all soft drawings of connected load external and internal, street lighting detail etc.	<b>Design is in the scope of POWERGRID.</b>
3	Similarly In the HT panel where RMU, HT panel, there is no rating mentioned and how much KA rating required.	<b>HT Panel 11kV, 630A, 25kA</b>