

प्लॉट नं.54, अम्बे विद्यालय के सामने, समा-सावली रोड, वडोदरा – 390 024(गुजरात)
 Plot No. 54, Opp.Ambe Vidyalay, Sama-Savli Road, Vadodara – 390 024(Gujarat)
 दूरभाष:/Phone: (O) 0265-2577514, फैक्स:/Fax: 0265-2577514

पश्चिम क्षेत्र पारिषण प्रणाली-II, क्षेत्रीय मुख्यालय
 Western Region Transmission System – II, Regional Headquarters

Ref : WRTS-II/C&M/ Amendment I

Dtd:22.07.2020

To,

Prospective Bidders

Sub : Insulator Package-C for Procurement of Composite Long Rod Polymer Insulators for O&M requirement of 400kV Lines in WR-II.-Amendment to the bidding document
RFX No. 5002001261

Dear Sir,

1.0 This has reference to the following

1.1 **RFX No. 5002001261** issued to you for the subject package

1.2 The following clause stands amended as below:


Sr. No	Reference	Existing Provision	Amended Provision
1.	Annexure A BDS Qualifying Requirements	<p>1.1 Technical Experience:</p> <p>1.1 (a) The Qualified Manufacturer shall be a manufacturer of Composite Insulators. The bidder's experience should include the following:</p> <p>(i) The Qualified Manufacturer should have designed, manufactured, tested and supplied minimum 150 nos. of 160kN* or above rating Composite long rod insulators for 345kV or above voltage transmission lines /sub-stations and the same should have been in satisfactory operation-\$ for a minimum period of two years as on originally scheduled date of bid opening i.e. 19.08.2020.</p>	<p>1.1 Technical Experience:</p> <p>1.1 (a) The Qualified Manufacturer shall be a manufacturer of Composite Insulators. The bidder's experience should include the following:</p> <p>(i) The Qualified Manufacturer should have designed, manufactured, tested and supplied minimum 150 nos. of 160kN* or above rating Composite long rod insulators for 345kV or above voltage transmission lines /sub-stations and the same should have been in satisfactory operation-\$ for a minimum period of two years as on originally scheduled date of</p>

		<p>(* As per higher kN rating of Insulators covered under the package. 160kN is to be stipulated for 400kV – 210kN for 765kV AC)</p> <p>\$ Satisfactory operation under the above clauses means certificate issued by the Employer certifying the operation without any adverse remark for a minimum period of two years as on originally scheduled date of bid opening i.e. 19.08.2020.</p>	<p>bid opening i.e. 19.08.2020. Further for composite Insulators up to 400KV , if the domestic manufacturer does not meet the stipulated two years operational experience they can furnish an extended warranty of additional two years</p> <p>(* As per higher kN rating of Insulators covered under the package. 160kN is to be stipulated for 400kV – 210kN for 765kV AC)</p> <p>\$ Satisfactory operation under the above clauses means certificate issued by the Employer certifying the operation without any adverse remark for a minimum period of two years as on originally scheduled date of bid opening i.e. 19.08.2020.</p>
2	Sample Forms and Procedure		<p><u>Add new Form</u></p> <p>Form of undertaking by the bidder - warranty obligations for extended warranty of additional two (2) years over and above the warranty period specified for Composite Longrod Insulator package in line with the bidding documents regarding clause 1.1 a of QR. (Included as separate attachment with the amendment)</p>

2.0 All other terms & conditions shall remain the same

Thanking You,

Yours Sincerely,



(Soham Dey)

Asst. Mgr(C&M)