

Clarification-I for Package-C-Augmentation of transformation capacity at 765/400/220kV Agra (PG) S/S by 1x500 MVA, 400/220kV ICT at 400 KV Agra S/S under RTM.

S.No	Query	POWERGRID Reply
1	Bidder scope only Erection of the OEM Supplied Hybrid GIS Only. HV Tests will be OEM Scope only. Kindly confirm please.	Erection, testing and commissioning including HV test shall be under the scope of Bidder.
2	Bidder Requesting to Extant the Completion Time from 15 Months to 20 Months. Due to delivery lead time by OEM of CB, CT & BPI.	Completion Time shall be as specified in Bid Documents.
3	Supply of 220kV GIS/Hybrid Bay is not in Bidder scope. The given Spares all are not applicable for Bus Duscts & Air Bushings. Kindly confirm Supply of all the Spares will be in Bidder Scope or not.	Yes, supply of all the spares as per BPS is in the scope of bidder. Further, 220 kV Hybrid GIS is of Toshiba Make.
4	Kindly Confirm the Make of Existing Bus Bar & SAS	The Bus Bar Protection System is ABB make REB500. Existing SAS is also ABB make.