

प्लॉट नं.54, अम्बे विद्यालय के सामने, समा-सावली रोड, वडोदरा – 390 024(गुजरात)
Plot No. 54, Opp.Ambe Vidyalay, Sama-Savli Road, Vadodara – 390 024(Gujarat)
दूरभाष:/Phone: (O) 0265-2577514, फैक्स:/Fax: 0265-2577514

पश्चिम क्षेत्र पारेषण प्रणाली-II, क्षेत्रीय मुख्यालय
Western Region Transmission System – II, Regional Headquarters

Ref : WRTS-II/C&M/Clarification & Bid Extension II

Dtd:15.12.2020

To,

Prospective Bidders

Sub : Clarification II: Supply & Delivery of Non-standard Design Towers for 400KV D/C Vindhyachal Jabalpur and 400 KV Jabalpur-Itarsi Transmission lines of WR-II RFX No. 5002001173

Dear Sir,

1.0 This has reference to the following

1.1 RFX No. 5002001388 issued to you for the subject package

1.2 The clarification to the queries raised by prospective bidders are as below:

Sr. No.	Clause Reference	Query Raised by Prospective Bidder	Clarification
1	Scope of Work & Amendment II	Whether destructive testing has to be conducted	Yes. Destructive test needs to be conducted
2	Scope of Work & Amendment II	How many load cases are to be included	Total 13 cases (i) Bolts Slip Test : No. : 01 (ii) Reliability Test : Nos : 01 (iii) Security : Nos : 08 (iv) Safety : No : 02 (v) Upto Destruction : 01
3	Scope of Work & Amendment II	Whether change in rigging needs to be considered	The same is Not Applicable

4	Scope of Work & Amendment II	Number of steel samples required for mechanical tests	As per POWERGRID SMQP
---	------------------------------	---	-----------------------


1.3 The tender fee and bid submission deadline is revised as below

Deadline of Tender Fee Submission	21.12.2020 at 17:30hrs
Deadline of Bid Submission Soft Copy Part	24.12.2020 at 15:00hrs
Deadline of Bid Submission Hard Copy Part	24.12.2020 at 15:00hrs
Bid opening Technical Part	24.12.2020 at 15:30hrs

2.0 The clarification shall form part of the Bid Document. Further all other terms & conditions shall remain unaltered.

Thanking You,

Yours Sincerely,



(Soham Dey)

Asst. Mgr(C&M)