



(भारत सरकार का उद्यम)

## **POWER GRID CORPORATION OF INDIA LIMITED**

(A Government of India Enterprise)

प्लाट नं.54, अम्बे विद्यालय के सामने, समा-सावली रोड, वडोदरा – 390 024(गुजरात) Plot No. 54, Opp.Ambe Vidyalay, Sama-Savli Road, Vadodara – 390 024(Gujarat) दूरभाष:/Phone: (O) 0265-2577514, फैक्स:/Fax: 0265-2577514

पश्चिम क्षेत्र पारेषण प्रणाली-II, क्षेत्रीय मुख्यालय

Western Region Transmission System – II, Regional Headquarters

Ref: WRTS-II/C&M/Clarification & Bid Extension I

Dtd:02.12.2020

To,

Prospective Bidders

Sub: Clarification I: Supply & Delivery of Non-standard Design Towers for 400KV D/C Vindhyachal Jabalpur and 400 KV Jabalpur-Itarsi Transmission lines of WR-II RFX No. 5002001173

Dear Sir,

- 1.0 This has reference to the following
- 1.1 **RFx No. 5002001388** issued to you for the subject package
- 1.2 The clarification to the queries raised by prospective bidders are as below:

Sr.	Clause	Query Raised by	Clarification
No.	Reference	Prospective Bidder	
1	Scope of Work & Amendment II	Whether there will be testing for 02 types of Towers separately	No. Proto Type Testing is to be carried out on A2+0 (Normal Suspension) Tower only.
2	Scope of Work & Amendment II	Tower Testing is to be done with (i) Destruction or (ii) Without Destruction	Tower Testing is to be done with Destruction only to check the ultimate Tensile Strength of the designed tower.
3	Scope of Work & Amendment II	In case of Tower Test Failure, how and who will bear the cost of retest of Tower?	The design of the tower is in the scope of the agency. Agency has to provide the successful design of the tower to POWERGRID.
4	Scope of Work & Amendment II	Providing Tower Drawings to agency in Auto CAD format? Agency has to make structural drawing?	Tower drawings are not available in Auto CAD format. BOM of the Tower shall be provided to Agency and Agency has to prepare the shop sketches as well as structural drawings.

5	Scope of Work	In order to quote for tower	Tower Testing Parameters as requested
	&	testing as per amendment,	is attached as <b>Annexure</b> : <b>Parameters of</b>
	Amendment II	please provide the tower	towers to be tested with this
		design details.	clarification. Please refer the same for
			details

1.3 The tender fee and bid submission deadline is revised as below

Deadline of Tender Fee Submission	14.12.2020 at 17:30hrs
Deadline of Bid Submission Soft Copy Part	17.12.2020 at 15:00hrs
Deadline of Bid Submission Hard Copy Part	17.12.2020 at 15:00hrs
Bid opening Technical Part	17.12.2020 at 15:30hrs

2.0 The clarification shall form part of the Bid Document. Further all other terms & conditions shall remain unaltered.

Thanking You,

Yours Sincerely,



(Soham Dey)

Asst. Mgr(C&M)