

Clarification No. - 4 dated 14/08/2025 to the Bidding Documents for "BESS Package BESS-01 for Setting up of Battery Energy Storage System of 5MW/ 20MWh capacity co-located with 85 MW Solar PV Power Plant at Nagda, Ujjain, Madhya Pradesh." Specification No.: CC/NT/W-MISC/DOM/A00/25/06104

Sl. No.	Reference document	Reference Clause	Description as per Tender Specification	Bidder's Query	POWERGRID's Reply
1	Volume II "Technical Specifications for Battery Energy Storage System, Rev - 01" (3-0 BESS Model Technical Specifications -Rev-1)	8.2.3 Technical parameters Page 20 of 38	ix. IP Rating: Min. IP-20 (Indoor) or Min. IP-55 (Outdoor)	All outdoor rated PCS are available in IP-54 rating. So kindly consider IP-54 rating PCS. The Contractor can install a shed on top of the PCS.	Existing Provision of TS shall be prevail.