

## Bid Corrigendum

GEM/2024/B/5738972-C3

Following terms and conditions supersede all existing "Buyer added Bid Specific Terms and conditions" given in the bid document or any previous corrigendum. Prospective bidders are advised to bid as per following Terms and Conditions:

### Buyer Added Bid Specific Additional Terms and Conditions

1. Buyer Organization specific Integrity Pact shall have to be complied by all bidders. Bidders shall have to upload scanned copy of signed integrity pact as per Buyer organizations policy along with bid. [Click here to view the file](#)
2. Bidder shall submit the following documents along with their bid for Vendor Code Creation:
  - a. Copy of PAN Card.
  - b. Copy of GSTIN.
  - c. Copy of Cancelled Cheque.
  - d. Copy of EFT Mandate duly certified by Bank.
3. **Manufacturer Authorization:** Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid
4. Scope of supply (Bid price to include all cost components) : Only supply of Goods
5. Bidders can also submit the EMD with Account Payee Demand Draft in favour of Power Grid Corporation of India Limited payable at Lucknow  
. Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.
6. Bidders can also submit the EMD with Banker's Cheque in favour of Power Grid Corporation of India Limited payable at Lucknow  
. Bidder has to upload scanned copy / proof of the BC along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.
7. Successful Bidder can submit the Performance Security in the form of Account Payee Demand Draft also (besides PBG which is allowed as per GeM GTC). DD should be made in favour of Power Grid Corporation of India Limited payable at Lucknow  
. After award of contract, Successful Bidder can upload scanned copy of the DD in place of PBG and has to ensure delivery of hard copy to the original DD to the Buyer within 15 days of award of contract.
8. Buyer Added text based ATC clauses

**"Supply of Surge Arresters and Accessories of Different Ratings for Various Substations of NR-I, NR-II, NR-III, WR-I, W**

## **R-II, SR-II and NER of POWERGRID”**

### **Specification No.: NCN0073**

**\* The detailed address of each location mentioned in Technical Specification. Bidders shall quote their prices with reference to locations mentioned.**

**Pre-Bid Meeting shall be conducted on 14.01.2025 at 11:00 am**

**(In Hybrid Mode). Request for providing link for**

**participation in online Pre-Bid Meeting shall be sent by**

**bidder through e-mail at [cpc@powergrid.in](mailto:cpc@powergrid.in)**

### **Venue for Physical Meeting:**

**Centralized Procurement Cell,**

**3<sup>rd</sup> Floor, Plot No. - 2A/INS 02, Avadh Vihar Yojna,**

**Amar Shaheed Path, Near Medanta Hospital**

**Lucknow- 226002 (UP)**

### **CORRIGENDUM-I**

**GEM BID REF. NO. GEM/2024/B/5738972 dated 07.01.2025**

<b>S.No.</b>	<b>Clause No.</b>	<b>Bidder's Query</b>	<b>Reply</b>
1	General	Short Circuit Current of 220kV LA to be confirmed. Is it 40kArms or 50kArms	Short Circuit Current of 220kV (nominal system operating voltage) LAs to be considered as 50kA rms.
2	General	For 120kV 10kA Class 2 LA & 132kV 20kA Class 4 LA, - is Polymer housing only acceptable?	Housing shall be strictly as per TS attached for 120kV 10kA Class-2 LA and 132kV 20kA Class-4 LA, i.e., Polymer/Composite Insulator Housing.
3	General	In the TS of 120kV 10kA CI2 & 132kV 20kA Class 4 LA, it is indicated that structures are to be supplied along with the IB & SM, is it required? Further for all other LAs as per SA Rev13 TS, structures are not required, this also is to be confirmed	Structures are not required to be supplied with Surge Arresters.

4	General	We find the requirement of Terminal Connectors indicated as separate Item for the requirement LAs in NR-3, WR-2, SR-2 & NER and not indicated for the LAs in other Regions - NR-1, NR-2, WR-1. Hence please conform the LAs does not include TC for these regions.	For all other LAs except for requirement mentioned for NR-III, WR-II, SR-II and NER, LAs are to be supplied with Terminal Connectors.  The details of Terminal Connectors for these LAs will be provided during detailed Engineering. The updated <b>Revised Scope of Work attached at buyer uploaded ATC.</b>
5	General	We find in NR-3 for 624kV LAs - though the quantity of LAs are 5 the TC requirement mentioned as 7. Please clarify	The quantity of LAs and TCs for NR-III is correct.
6	General	Is it mandatory for the Bidder to quote for all items or do we have the option of not quoting for certain items.	It is mandatory for the Bidder to quote for all items.
7	General	we wish to inform you that for the subject Tender - PGCIL R13 Spec - is enclosed to the Bid document for consideration / compliance. Please note as per R13 Spec - we have to consider Junction Box also for a set of 3 LAs. Hence, please confirm whether Junction Box to be considered, since if the LAs are for replacement, then Junction Box may not be required.	The Junction Box are not required to be supplied with Surge Arresters.
8	General	we find the BOQ indicated in the Revised scope of work - Annexure 01 (copy attached) does not match with the BOQ specified in the GEM document (copy attached) in totality.  Kindly confirm which one to be considered for Bid submission	Prices to be quoted as per BoQ and <b>Revised Scope of Work attached at buyer uploaded ATC.</b>
9	General	Corona Ring is required for 624kV Surge Arresters. For Surge Arresters with Voltage Ratings below 624kV i.e. 390kV, 336kV, 216kV, 132kV, 120kV and 60kV Corona Ring is Not Applicable. However, under "Scope of Work" - Annexure-01, Corona Ring is mentioned in the scope of supply for all the Voltage Ratings of Surge Arresters. Kindly remove Corona Ring from the "Item Description" for all the Voltage Ratings of Surge Arresters below 624kV.	As per attached TS, Corona rings shall be provided on each complete arrester unit, as required.

10	General	The Item Description DOES NOT contain Terminal Connectors in the Scope of Supply of various voltage ratings of Surge Arresters. Kindly clarify that the Terminal Connectors are NOT included in the Scope of Supply of the Surge Arresters. Also, it is requested to incorporate "Without Terminal Connector" in the Item Description of the Surge Arresters	Terminal Connectors have been indicated as separate Item for consignees of NR-II, WR-II, SR-II and NER. For all other consignees except for NR-III, WR-II, SR-II and NER, LAs are to be supplied with Terminal Connectors. The details of Terminal Connectors for these LAs will be provided during detailed Engineering.  <b>Revised Scope of Work attached at buyer uploaded ATC.</b>
11	General	The No. of Terminal Connectors are NOT same as the No. of Surge Arresters. Kindly clarify that the Bid may be submitted as per the BOQ Qty for Terminal Connectors even if there is a mismatch in the Qty of the Terminal Connectors vis-a-vis the Qty of the Surge Arresters.	Terminal Connectors have been indicated as separate Item for consignees of NR-3, WR-2, SR-2 and NER. For all other consignees except for NR-3, WR-2, SR-2 and NER, LAs are to be supplied with Terminal Connectors. The details of Terminal Connectors for these LAs will be provided during detailed Engineering.  <b>Revised Scope of Work attached at buyer uploaded ATC.</b>

**Accordingly, attachments at buyer uploaded ATC document is updated & attached to this corrigendum.**

**This corrigendum shall form an integral part of the bid documents and shall be read in conjunction with the same.**

9. Buyer uploaded ATC document [Click here to view the file.](#)

## Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for

[attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)

9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

\*This document shall overwrite all previous versions of Bid Specific Additional Terms and Conditions.

[This Bid is also governed by the General Terms and Conditions](#)