

”

“Supply of 400 kV, 220 kV and 132 kV CTs for various Substations of NR-II, NR-III and NER of POWERGRID.

Specification. No.: NCN0169

CORRIGENDUM-I Dated 11.07.2025

GEM BID REF. NO. GEM/2025/B/6317329 Dated: 23-06-2025

Sl. No.	Clause No.	Bidder's Query	Reply
1.	TS	You are requested to share core wise technical details for 132kV CT 1200Amps which is not provided in standard PGCIL specifications.	Core wise technical details for 132kV CT 1200Amps is attached in Annexure-I
2.	General	We are interested to quote only 132 kV & 220 kV CT. Please allow us to participate in it.	Bidders need to quote for all the items in the package.
3.	General	Delivery – Since the lead time of polymer insulator itself is 6-7 months, we request to amend the delivery period as: Delivery shall be made in staggered/lot wise every month and shall be completed within 330 days from the date of PO.	Delivery period for subject package shall be 06 months (180 Days) from the date of placement of award as per bid document
4.	General	Unloading of material at site shall be in scope of purchaser.	Unloading of material at site shall be in the scope of supplier
5.	General	Please allow OEM for part bidding – quantity /rating wise	Bidders need to quote for all the items in the package.
6.	General	Minimum local content- As per the latest guideline, please allow MLC to be submitted by OEM on letter head.	Form-2 and Form 2A in BATC document may be referred for declaration of Minimum local content.

Annexure-I is uploaded in Buyer Uploaded ATC.

This corrigendum shall form an integral part of the bid documents and shall be read in conjunction with the bid documents.

ction with the same.

CORRIGENDUM-II Dated 19.09.2025

GEM BID REF. NO. GEM/2025/B/6317329 Dated: 23-06-2025

Following Terms and Conditions of above referred GeM Bid are Amended as indicated below:

Sl. No.	Clause No.	Existing provision	Reply	This
1.	Sl. No. 20 of Buyer uploaded ATC (GTC clause 14)	The delivery schedule for the Goods and Related Services to be supplied under the Contract shall be 180 days from the date of Contract Order generated through GeM portal.	The delivery schedule for the Goods and Related Services to be supplied under the Contract shall be 12 months from the date of Contract Order generated through GeM portal	
2.	Sl. No. 15 (GTC Clause 7(ii))	In case the Performance Security/CPG is submitted in form of a Bank Guarantee/Insurance Surety Bond, the validity of the Bank Guarantee/ Insurance Surety Bond shall be 20 months .	In case the Performance Security/CPG is submitted in form of a Bank Guarantee/ Insurance Surety Bond , the validity of the Bank Guarantee/ Insurance Surety Bond shall be 26 months .	

corrigendum shall form an integral part of the bid documents and shall be read in conjunction with the same.

CORRIGENDUM-III Dated 19.09.2025

GEM BID REF. NO. GEM/2025/B/6317329 Dated: 23-06-2025

Following Terms and Conditions of above referred GeM Bid are Amended as indicated below:

Sl. No.	Clause No.	Existing provision	Reply	As s
1.	Sl. No. 20 of Buyer uploaded ATC (GTC clause 14)	The delivery schedule for the Goods and Related Services to be supplied under the Contract shall be 180 days from the date of Contract Order generated through GeM portal.	The delivery schedule for the Goods and Related Services to be supplied under the Contract shall be as below from the date of Contract Order generated through GeM portal. <u>For 400KV & 220 KV CTs: 12 Months</u> <u>For 132KV CTs: No Change</u>	

2.	Sl. No. 15 (GTC Clause 7(ii))	In case the Performance Security/CPG is submitted in form of a Bank Guarantee/Insurance Surety Bond, the validity of the Bank Guarantee/ Insurance Surety Bond shall be 20 months.	In case the Performance Security/CPG is submitted in form of a Bank Guarantee/ Insurance Surety Bond , the validity of the Bank Guarantee/ Insurance Surety Bond shall be 26 months.
----	----------------------------------	---	---

uch, **CORRIGENDUM-II Dated 19.09.2025 stands deleted.**

This corrigendum shall form an integral part of the bid documents and shall be read in conjunction with the same.

8. Buyer uploaded ATC document [Click here to view the file.](#)

Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of

Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

*This document shall overwrite all previous versions of Bid Specific Additional Terms and Conditions.

[This Bid is also governed by the General Terms and Conditions.](#)