

Clarification-IV to Bidding Documents for Transformer Package TR34 for a) Supply of 1X 500MVA, 420/220/33kV Auto transformer at Bhadla pooling S/S including associated bays, b) Supply of 1X 500MVA, 420/220/33kV Auto transformer at Shujalpur S/s including associated bays, c) Extension of 220kV Shajhanpur S/S, d) Implementation of 1X 80 MVAR , 765kV Spare Reactor at Bhadla S/S, e) Supply of 1X 500MVA, 420/220/33kV Auto transformer at Kohchi S/S, f) Supply of 1X 500MVA, 420/220/33kV Auto transformer at Hiriyur S/S associated with New ISTS Schemes to be developed under RTM mode. Spec. No. 5002001872/TRANSFORMER/DOM/A03-CC CS-4

S. No.	Clause No.	Text as per bid document	Bidder Query	Clarification
1.	Volume-II Part-1 of 13 0.1 Section Project along with Annexures & Clarification-II	The design of foundation shall be based on the soil investigation report and other parameters as per relevant IS codes & technical specification. The foundations may be open foundation or pile foundation as per the site requirement / soil report. Soil investigation report shall be provided to successful bidder during detailed engineering stage.	We like to clarify that Open and pile foundations are entirely different type of foundations. The price implication between the two type of foundation is huge. Kindly clarify the type of foundation envisaged in the package. Further the BOQ does not contain item for piling. If piling is envisaged same is to be added in the BOQ.	Pile foundations are not envisaged for Bhadla, Bhadla- II, Shahjahanpur and Shujalpur S/s.