

Bid Corrigendum

GEM/2026/B/7158148-C12

Following terms and conditions supersede all existing "Buyer added Bid Specific Terms and conditions" given in the bid document or any previous corrigendum. Prospective bidders are advised to bid as per following Terms and Conditions:

Buyer Added Bid Specific Additional Terms and Conditions

1. Buyer Organization specific Integrity Pact shall have to be complied by all bidders. Bidders shall have to upload scanned copy of signed integrity pact as per Buyer organizations policy along with bid. [Click here to view the file](#)
2. Bidder shall submit the following documents along with their bid for Vendor Code Creation:
 - a. Copy of PAN Card.
 - b. Copy of GSTIN.
 - c. Copy of Cancelled Cheque.
 - d. Copy of EFT Mandate duly certified by Bank.
3. **Manufacturer Authorization:** Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid
4. Supplier shall ensure that the Invoice is raised in the name of Consignee with GSTIN of Consignee only.
5. Without prejudice to Buyer's right to price adjustment by way of discount or any other right or remedy available to Buyer, Buyer may terminate the Contract or any part thereof by a written notice to the Seller, if:
 - i) The Seller fails to comply with any material term of the Contract.
 - ii) The Seller informs Buyer of its inability to deliver the Material(s) or any part thereof within the stipulated Delivery Period or such inability otherwise becomes apparent.
 - iii) The Seller fails to deliver the Material(s) or any part thereof within the stipulated Delivery Period and/or to replace/rectify any rejected or defective Material(s) promptly.
 - iv) The Seller becomes bankrupt or goes into liquidation.
 - v) The Seller makes a general assignment for the benefit of creditors.
 - vi) A receiver is appointed for any substantial property owned by the Seller.
 - vii) The Seller has misrepresented to Buyer, acting on which misrepresentation Buyer has placed the Purchase Order on the Seller.
6. Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods
7. Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.
8. Bidders can also submit the EMD with Account Payee Demand Draft in favour of Power Grid Corporation of India Limited payable at Lucknow.
9. Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.
9. Bidders can also submit the EMD with Banker's Cheque in favour of Power Grid Corporation of India Limited

payable at
Lucknow

Bidder has to upload scanned copy / proof of the BC along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

10. Buyer Added text based ATC clauses

“Supply and Installation of 1000 kVA DG Sets to replace Old DG Sets at Rih and (NR-III) and Dadri (NR-I) Sites of POWERGRID”

Specification. No.: NCN0259

GeM CORRIGENDUM-I

GeM Bid ref. no. GEM/2026/B/7158148 Dated: 12-02-2026

- A) Following Terms and Conditions of above referred GeM Bid are amended as indicated below:**

As per BATC of GeM Bid		Amended provision
GTC Clause Ref. No.	Amendment/Supplement to GTC	
GTC clause 4.0, x iii(m)	BATC Sl. No. 4 (8.0) Those MSE Bidders (based on the documents submitted in the Bid) who have not claimed “EMD exemption” in GeM for the specific package, EMD exemption benefits shall not be extended as per the GeM procedures/ policies.	- Stands deleted-

This GeM Corrigendum-I shall form an integral part of the bid documents and shall be read in conjunction with the same.

CORRIGENDUM-II

GEM BID REF. NO. GEM/2026/B/7158148 Dated: 12-02-2026

Following are the reply to the queries raised:

Sl. No.	Clause No./TS/ SoW	Query	Reply to the query
----------------	---------------------------	--------------	---------------------------

1	SoW	Please confirm exhaust structure requirement separately for each DG set or 02 nos.	Separate exhaust system for each DG Set is required. However, exhaust structure (to support separate exhaust pipes) requirement shall be as per approved layout plan and foundational drawing at the time of drawing approval during detailed engineering after issue of award.
2		Please confirm whether Synchronization panel required.	Synchronization panel is not required.
3		Please share complete details of AMF panel and other panel required.	AMF panel required as per Para 9 & 10 of Scope of Work and as per Clause 6.0 of Technical Specification.
4		Please confirm the total length for cable tray	Approximate distance for laying of new Power cables shall be 200meter each run and 80 meter each run respectively. Necessary cable trays for laying cables wherever POWERGRID cable trenches/trays are not available along this route, same shall be required to be supplied and installed by the bidder. It is to mention here that old cables are already laid on cable trays, the same shall be utilized. However, for some portion along the newly laid cable length, new cable trays shall be supplied and installed by bidder. The bidders are advised to visit the site for better understanding

5	Control cable details are not mentioned in the tender only power cable requirement provided of 1C x 630 Sqmm.	Existing control cable laid from ACB/POWERRID SCADA to existing DG AMF panel shall be utilized by the bidder. Dismantling of above control cable from DG AMF panel side and termination to new AMF panel shall be in the scope of bidder. Any new control cable required for control/communication among DG set, AMF panel and Fuel tank to be supplied under this package shall be supplied, laid and terminated by supplier as per scheme approved during detailed engineering after issue of award.
6	FAT mentioned for 12 hrs, is it required for each DG set.	FAT is required for each DG set in line with scope of work, technical specifications, and relevant standards.
7	POL for site acceptance test to be provided by PGCIL.	Kindly refer clause 13 of scope of work included in tender document.
8	Tender estimated cost required.	Tender estimated cost cannot be disclosed at this stage
9	Scope of earthing and type of earthing	Earthing shall be in the scope of bidder and GI earthing is required as per Standard IS 3043.
10	Scope of first fill of diesel up to capacity	Refer Clause 13 of Scope of Work included in tender document
11	Potential free contacts required for further communication or not or IEC 61850.	Potential free contacts are required, please refer clause 9 and 10 of scope of work included in tender document.
12	DG Incomer ACB in ACDB.	ACB is already installed and separate ACB is not required for DG Set. Refer Clause 2 (e) of Scope of Work included in tender document.
13	Nearest building at DG Set location	Building is located very near to DG set location approx. 30 mt. As per scope of work Clause 1, Bidders are advised to visit the site for better understanding.

14		we will provide the provision of communication at RS 485 port / potential free contacts	Acceptable
15		Clear scope of dismantling or shifting of DG Set with distance of shifting, if any	Shifting shall be done within substation premises approx. 300 m from the existing DG location.
16		Ambient Design Temperature	Ambient Design Temperature is 50deg C
17	SoW	Criteria for Gate Pass Entry and documents required.	Gate passes are required to be arranged in advance prior to start of work/enquiry. Below mentioned documents shall be required <u>for manpower: -</u> a) Identity Proof b) WC Policy c) Police verification d) Medical Fitness <u>For Vehicle</u> a) RC b) Insurance c) Fitness d) other paper related to vehicle.

This GeM Corrigendum-II shall form an integral part of the bid documents and shall be read in conjunction with the same.

11. Buyer uploaded ATC document [Click here to view the file.](#)

Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to

exemption provided to such sellers under GeM GTC.

3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

*This document shall overwrite all previous versions of Bid Specific Additional Terms and Conditions.

[This Bid is also governed by the General Terms and Conditions](#)