

संदर्भ/Ref : CC-ENGG-CS0PKG20-1001307-SE0144-OD-SWITCHYARD-ILUMN

Date : 04/02/2022

From : Arindam Chakraborty
Chief GM

To : M/s Tata Projects Limited
1st Floor, Tower-1, Okaya Center, B-5
Sector-62
Noida-201301, Uttar Pradesh

Cc : ENGG-SS

Subject : Scope of balance work includes - Construction of 7 no. new 33/11 kV Substation, erection of 165 km of 33 kV S/C line and 2km of 33kV D/C line, Construction of 2 no of line bays, laying of 129 km of OPGW and 55km of ADDS F/optic cable at risk & cost of M/s Technofab Engineering Ltd

LOA Ref : CC-CS /1056-NER/REW-4166/3/G2/CA-I/9104&CA-II/9105 Dated 15/01/2021

Please find enclosed following drawings/ documents for necessary action at your end.

Vendor Drg. No. : TD-200257-TPL-PGCIL-ARP-DMS-02-TRI-LL-7045
Orgn. Drg. No. : CS0PKG20-1001307-SE0144-OD-SWITCHYARD-ILUMN
Revision No. : 00
Drg. Title : Trizino-Outdoor/Switchyard Illumination
App. Category : CAT-I
Release Date : 04/02/2022



Scan to verify

Comments : CAT I

अनुमोदित श्रेणी/App. Category:

- I. फेब्रिकेशन/निर्माण/टाइप टेस्टिंग हेतु जारी।
Approved/released for fabrication/construction.
- II. फेब्रिकेशन/निर्माण/टाइप टेस्टिंग हेतु अनुमोदित/जारी बशर्ते दिए गए टिप्पणियाँ एवं आशोधनों की सम्मिलित किया जाये। कृपया रियाइज्ड दस्तावेज अनुमोदनार्थ प्रस्तुत करें।
Approved/released for fabrication/ construction subject to incorporation of comments and modification as noted. Revised drawing required for approval.
- III. टिप्पणियाँ सम्मिलित करने के उपरान्त दस्तावेज को अनुमोदनार्थ प्रस्तुत करें।
To be resubmitted for approval after incorporating the comments.
- IV. सूचनार्थ एवं रिकार्ड हेतु।
For information and record.
- REL-CON निर्माण हेतु जारी।
Released for construction.

नोट/Note:

1. Approval/Comments conveyed herein neither relieve the contractor of his contractual obligations and his responsibilities, weights, quantities, design details assemble fits, performance particulars and conformity of the supplies with the Indian Statutory Laws as may be applicable, nor does it limits the purchaser's right under the contract.
2. The approval conveyed vide this letter does not cover the approval of make for sub-vendor items.

केन्द्रीय कार्यालय: "सौदामिनी", प्लॉट नंबर 2, सेक्टर -29, गुरुग्राम -122001, (हरियाणा) दूरभाष: 0124-2571700-719

Corporate Office: "Saudamini", Plot No. 2, Sector-29, Gurugram-122001, (Haryana) Tel.: 0124-2571700-719

पंजीकृत कार्यालय: बी-9, कुतब इंस्टीट्यूशनल एरिया, कटवारीया सराय, नई दिल्ली -110016. दूरभाष: 011-26560112, 26560121, 26564812, 26564892, सीआईएन: L40101DL1989GOI038121

Registered Office: B-9, Qutab Institutional Area, Katwaria Sarai, New Delhi-110016. Tel: 011-26560112, 26560121, 26564812, 26564892, CIN : L40101DL1989GOI038121
Website: www.powergridindia.com

APPROVED

BILL OF MATERIAL	
SL NO	SYMBOL
1.	→
2.	⊙
3.	⊞
4.	⊞
5.	⊞
6.	⊞

NOTE -
1. ALL DIMENSIONS IN METERS
2. LIGHTING FIXTURES
3. LIGHTING CABLES
4. LIGHTING OF ROOF
5. THE LOCATION OF
LEGEND FOR AC

LP → RI → N

SYMBOLS	DESCRIPTION
→	150W LED OR EQUIVALENT
⊙	63A OUTDOOR SA OUTDOOR
	TOTAL LOAD
	AREA

LIGHTING FIXTURE SCHEDULE		
FITTING LOCATION	LUMINARY No.	MOUNTING HEIGHT (METER)
LP & TOWER GALLERY	LF01	7.5
	LF02	7.5
	LF03	7.5
	LF04	7.5
	LF05	7.5
	LF06	7.5
	LF12	7.5
	LF07	6.5
	LF08	5.5
	LF09	5.5
	LF10	5.5
	LF11	5.5

00	25.01.2022	FIRST
REV.	DATE	DESCR
LOA NO.		CC-C
OWNER		DEPAR
CLIENT		
CONTRACTOR		
PROJECT.		PACK STRE STATE
DESCRIPTION		OUTD
SCALE NTS.	SH. NO. 1 OF 1	DRG.