



पावर ग्रिड कारपोरेशन ऑफ इंडिया लिमिटेड
(भारत सरकार का उद्यम)
POWER GRID CORPORATION OF INDIA LIMITED
(A Government of India Enterprise)



केन्द्रीय कार्यालय: "सौदामिनी" प्लॉट सं. 2, सैक्टर-29, गुडगाँव-122 001, (हरियाणा) दूरभाष: 0124-2571700-719, फैक्स : 0124-2571762,
"Saudamini" Plot No. 2, Sector-29, Gurgaon-122 001, (Haryana) Tel. : 0124-2571700-719, Fax : 0124-2571762, Web.: www.powergridindia.com

Ref: CP/RTI /2014/82

Date: 09.09.2014

Shri A K Bajaj
C.E.O Transmission, A2Z
Maintenance & Engineering Services Limited
116, first Floor, Shopping Mall, Arjun Marg
DLF City-I Gurgaon-122002

Sub: **Information under Right to Information Act, 2005.**

Dear Mr. Bajaj,

This has reference to your letter dated 01st August 2014 for seeking information under RTI Act, 2005.


The information sought is given below.

9. Total 36 Nos of fatal accidents have occurred during construction since 01.01.2013 to 30.06.2014. (Details attached as Annex-I)
10. The details regarding fatal accidents, have been provided in Section-II, Instruction to bidders (ITB) and Section-III, Bid Data Sheets (BDS) , Volume-I of the Bidding documents for (Supply-cum-Installation) packages under domestic funding. Further, it may be noted that the Bidding documents are available on POWERGIDs website www.powergridindia.com.
11. Provisions for such rules, as amended from time to time, were available in the Bidding Documents for the packages for which bids opened after January 2012.
12. A large number of contracts have been awarded during the last two years and the information sought is available in the respective contract files. Accordingly, gathering of the information would disproportionately divert the resources of the public authority. As such the information may be provided, if you specify the name of the contract.
13. 6 Nos. Accidents reports enclosed separately (Annex-II).

Details of Appellate Authority, as per the provisions of RTI Act, 2005 is as under

Shri B. Mishra
Executive Director (CP & IT) & Appellate Authority, Corporate Centre
Power Grid Corporation of India Limited
"Saudamini", Plot No. 2, Sector-29
Gurgaon – 122007, Haryana

Thanking You,


भवदीय, 9.9.14

(सुधीर मित्तल)

महाप्रबंधक(के.आ.)एवंके.लो.सू.अधिकारी

Details of Fatal Accidents during construction during the period from 01-01-2013 To 30-06-2014

Sl. No.	Date of Accident	NAME OF CONTRACTOR	No of Persons suffered fatality
1	09-01-2013	M/S SIEMENS	3
2	12-01-2013	M/S JOTHI STRUCTURES LTD.,	1
3	07-02-2013	M/S KPTL	1
4	21-02-2013	M/S GAMMON INDIA LTD.,	1
5	24-02-2013	M/S GAMMON INDIA LTD.,	1
6	27-02-2013	M/S INABENSA	1
7	06-03-2013	M/S KPTL	1
8	28-03-2013	M/S ASTER	5
9	19-04-2013	M/S LANCO INFRA TECH.LTD.,	3
10	05.05.2013	M/S SHYAMA POWER CO. LTD.	5
11	14-05-2013	M/S A2Z MAINTENANCE & ENGG	1
12	15-05-2013	M/S JYOTI STRUCTURES LTD	1
13	23-06-2013	M/S JYOTI STRUCTURES LTD.,	1
14	06-08-2013	M/S GAMMON	1
15	25-09-2013	M/S NAGARJUNA CONSTR CO LTD.,	1
16	29.09.2013	M/S EMC LTD.,	1
17	20-10-2013	M/S JYOTI POWER CORPORATION	1
18	17-11-2013	M/S KPTL	1
19	29-11-2013	M/S JYOTI POWER CORPORATION	1
20	13-12-2013	M/S NATIONAL CONTRACTING COMPANY	2
21	30-12-2013	M/S VIJETA PROJECT & INFRASIT LTD.,	1

22	02-01-2014	M/S KPTL	1
23	12-01-2014	M/S KEC	1
24	18-01-2014	M/S GAMMON INDIA LTD.,	1
25	21.01.2014	M/S KPTL	3
26	29-01-2014	M/S EMC	1
27	26-02-2014	M/S BAJAJ ELECTRICALS	1
28	08-03-2014	M/S KPTL	1
29	03.04.2014	M/S SHYAMA POWER	1
30	14.04.2014	M/S ASTER PVT LTD	1
31	18.04.2014	M/S L& T LTD	1
32	10.05.2014	M/S BAJAJ ELECTRICALS	1
33	11.05.2014	M/S SHYAMA POWER	1
34	22.05.2014	M/S KPTL	1
35	25.06.2014	M/S DEEPAK CABLES LTD	1
36	27.06.2014	M/S INABENSA	1
Page:2 of 2			

G. Nal...
21/01/2014
D G M (CS) / 2C

POWER GRID CORPORATION OF INDIA LIMITED**ACCIDENT REPORT**

1 Date & Time of Accident : 9/1/2013 17:00hrs

2 Nature of Accident (Fatal/Non-Fatal) : Fatal

3 Accident Place : 400/220kV GIS Building
(Name of Tr. Line Tower/Location No. or S/S, District/State) :

4 Nature of Work : Slab Casting of GIS Building

5 Name of Agency (POWERGRID/Contractor) : M/s SIEMENS

6 Name of Injured Person /Persons) :

i) Father's Name

ii) Address

iii) Designation

iv) Age

v) Marital Status (Married or Un married)

Fatal	Non Fatal
1) Vijay	1) Sikandar
Ramesh Urawn	
Jharkhand	
worker	worker
28 yrs	27 yrs
Married	
2) Nand Ram	2) Sanjay
Bahadur	
Nepal	
worker	worker
42	21 yrs
Married	
3) Daniel	
Massidas	
Jharkhand	
worker	
29	
Married	

7 First Aid Given to the injured after accident : At local hospital,
(If yes, Name of person or hospital/dispensary)

8 Name of hospital (Admitted for treatment) : hamirpur

9 Brief Report about accident :
Slab was casted and final finishing was under progress. Suddenly whole slab collapsed in single go due to which 3 labours who were inside the building under the slab apparantly carrying out final checking of scaffold died. Minor injuries were caused to 2 workmen.

POWER GRID CORPORATION OF INDIA LIMITED

ACCIDENT REPORT

- 1 Date & Time of Accident : 28/03/2013;10:00hrs
- 2 Nature of Accident (Fatal/Non-Fatal) : Fatal
- 3 Accident Place : 765kV S/C Agra-Jhatikara T/L
(Name of Tr. Line Tower/Location No.) 63C/0
- or S/S,District/State
- 4 Nature of Work : Stringing
- 5 Name of Agency (POWERGRID/Contractor) : M/s ASTER

- 6 Name of Injured Person /Persons)
- i) Father's Name
- ii) Address
- iii) Designation
- iv) Age
- v) Marital Status (Married or Un married)

Fatal		
1) Sheik Rintu	2) Israil Momin	3) Mokhtarul Momin
Sheik Majboon	Mosed Momin	Ramzan Momin
E.Bazar, Malda	E.Bazar, Malda	E.Bazar, Malda
Worker	Worker	Worker
24 yrs.	22 yrs	20 yrs
Unmarried	Unmarried	Unmarried
4) Sabirul Sheik	5) Munnial Hemrom	
Jalil Sheik	Kanti Hemrom	
E.Bazar, Malda	E.Bazar, Malda	
Worker	Worker	
25 yrs	24yrs	
Unmarried	Married	
Non-Fatal		
Md.Barik Momin	Sheik Sintu	
Anis Momin	Takbul	
E.Bazar, Malda	Lakshmighat, Malda	
Worker	Worker	
29 yrs	22 yrs	
Married		

- 7 First Aid Given to the injured after accident : Al fia Hospital
(If yes, Name of person or) : Mewat
hospital/dispensary
- 8 Name of hospital (Admitted for treatment) : Govt Medical college
Nuh
- 9 Brief Report about accident : Final sagging works was under progress at above said location.
During Load taking the Tower got twisted and collapsed causing death of 5 workers and injuring 8 others

POWER GRID CORPORATION OF INDIA LIMITED

ACCIDENT REPORT

- 1 Date & Time of Accident : 19/04/2013;13:00hrs
- 2 Nature of Accident (Fatal/Non-Fatal) : Fatal
- 3 Accident Place : 765kV S/C Champa-Raigarh T/L
(Name of Tr. Line Tower/Location No. or S/S,District/State) Loc.No. 15/0 (D+3)
- 4 Nature of Work : Stringing Work
- 5 Name of Agency (POWERGRID/Contractor) : M/s LANCO Infra Tech

- 6 Name of Injured Person /Persons)
- i) Father's Name
- ii) Address
- iii) Designation
- iv) Age
- v) Marital Status (Married or Un married)

Fatal	Non Fatal
1) Sh.Kaptan Singh	1) Rambabu
S/o Chandan Singh	S/o Dhan Raju
Bandra ,UP	UP
Fitter	Fitter
32 yrs.	22 yrs.
2)Sh.Satyanarayana	2) Shiv Lakhan Yadav
S/o Badalwa	Bachraj Yadav
Bandra ,UP	UP
Fitter	Fitter
36 yrs.	Age 22 yrs.

- 7 First Aid Given to the injured after accident :
(If yes, Name of person or hospital/dispensary)

- 8 Name of hospital (Admitted for treatment) : Govt Hospital,Raigarh

- 9 Brief Report about accident

: At above said location final sagging was going on. Sagging operation of middle phase was completed.Left phase marking was done.During final sagging of right phase, tower collapsed and accident took place.The victims were immediately taken to Govt., hospital,Raigarh

POWER GRID CORPORATION OF INDIA LIMITED

ACCIDENT REPORT

- 1 Date & Time of Accident : 05/05/2013;17:45hrs
- 2 Nature of Accident (Fatal/Non-Fatal) : Fatal
- 3 Accident Place : 765kV S/C Champa-Korba T/L
(Name of Tr. Line Tower/Location No. or)
S/S,District/State
- 4 Nature of Work : Tower Erection works
- 5 Name of Agency (POWERGRID/Contractor) : M/s Shyama Power India Ltd.,
Fatal

6 Name of Injured Person /Persons)

- i) Father's Name
ii) Address
iii) Designation
iv) Age
v) Marital Status (Married or Un married)

1) Prakash Mahto	2) Bikash Mahato	3) Govardhan Singh
Manik	Dilchand	Chhedi
H'Bagh,J khand	H'Bagh,J khand	Giridih,J khand
Fitter	Fitter	Fitter
28	21	22
Married	Married	Married

4) Bholu Mahato	5) Hari Mahato
Giridhari	Kushal
Giridih,J khand	Giridih,J khand
Fitter	Fitter
35	22
Unmarried	Unmarried

- 7 First Aid Given to the injured after accident
(If yes, Name of person or hospital/dispensary) : At Local Hospital
- 8 Name of hospital (Admitted for treatment) : District Hospital,Janjgir.
- 9 Brief Report about accident : During lifting and fixing of beam at loc No 48/1 SE+25 tower sudden jerk occurred. Immediately one derrick pole bent and tower collapsed from 2 nd section. All the fitters who climbed on the tower for fixing beam hit on the ground with the tower

POWER GRID CORPORATION OF INDIA LIMITED

ACCIDENT REPORT

1 Date & Time of Accident : 13/12/2013;10:30hrs.

2 Nature of Accident (Fatal/Non-Fatal) : Fatal

3 Accident Place : 765kV S/C Raichur-Sholapur T/L
(Name of Tr. Line Tower/Location No. or S/S,District/State) Loc.No 11/0 (SE+18)

4 Nature of Work : Stringing

5 Name of Agency (POWERGRID/Contractor) : M/s NCC Ltd.,
Fatal

6 Name of Injured Person /Persons) : 1) Sh Deshraj
i) Father's Name : Sitaram Nishad
ii) Address : Fatehpur,UP
iii) Designation : Skilled Fitter
iv) Age : 27 yrs
v) Marital Status (Married or Un married) : Married

2)Lal Mohmad
Abu Baker
Malda W.B
Skilled Fitter
24 yrs
Un Married

7 First Aid Given to the injured after accident : Yes
(If yes, Name of person or hospital/dispensary)

8 Name of hospital (Admitted for treatment) : Govt Hospital,Gabbur

9 Brief Report about accident : During installation of Pilot insulator string at left side cross arm of AP 11/0,failure of cross arm caused fatal injuries to 2 fitters



POWER GRID CORPORATION OF INDIA LIMITED

ACCIDENT REPORT

- 1 Date & Time of Accident : Considered on 21.01.2014 (25/02/2013;09:00hrs)
- 2 Nature of Accident (Fatal/Non-Fatal) : Fatal
- 3 Accident Place : 765kV S/C Chamradol- Satna T/L
(Name of Tr. Line Tower/Location No. or)
S/S, District/State
- 4 Nature of Work : Stringing works
- 5 Name of Agency (POWERGRID/Contractor) : M/s KPTL.,

6 Name of Injured Person /Persons)

- i) Father's Name
ii) Address
iii) Designation
iv) Age
v) Marital Status (Married or Un married)

Fatal		
1) Rajendra K Rawat	2) Sunil Turi	3) Manoj Ravidas
Dhunkai	Chandu Turi	Jagdish Ravidas
Fatehpur, U.P	Fatehpur, U.P	Fatehpur, U.P
Fitter	Fitter	Fitter
27 yrs	21 yrs	22yrs
Married	Un Married	Un Married

Injured		
1) Ram Narayan	2) Phool Chand	3) Birendra Kumar
AmarNadh	Ramavtar	Panna Lal
Fatehpur, U.P	Fatehpur, U.P	Fatehpur, U.P
Fitter	Fitter	Fitter
22	34	28

4) SriRam Singh
Heera Lal
Fatehpur, U.P
Fitter
39

7 First Aid Given to the injured after accident
(If yes, Name of person or hospital/dispensary)

8 Name of hospital (Admitted for treatment)

9 Brief Report about accident

: Govt Hospital, Baohari.

: While doing preparatory works for earth wire and other phases accident occurred due to sudden failure of stay of middle phase followed by failure of other stays causing collapse of tower