## पावर ग्रिड कारपोरेशन ऑफ इंडिया लिमिटेड

भारत सरकार का उद्यम)

#### POWER GRID CORPORATION OF INDIA LIMITED

(A Government of India Enterprise)



केन्द्रीय कार्यालय : ''सौदामिनी'' प्लॉट सं. 2, सैक्टर-29, गुडगाँव-122 001, हरियाणा फोन : 0124-2571700-719, फैक्स : 0124-2571760, 2571761 तार 'नेटग्निड' Corporate Office : "Saudamini" Plot No. 2, Sector-29, Gurgaon-122 001. Haryana Tel. : 0124-2571700-719, Fax : 0124-2571760, 0124-2571761 Gram : 'NATGRID'

संदर्भ संख्या / Ref. No.

C/CP/RTI/2015/186

Date: 28th January 2015

Shri Prem Prakash Prajapati Industrial Area, Khurai Road, Bina, Disst, Sagar M.P -470113

Sub: Information under Right to Information Act, 2005.

Dear Mr Prajapati,

This has reference to your RTI request dated 18<sup>th</sup> December 2014 (received on 29<sup>th</sup> December 2014) seeking information under RTI Act, 2005.

The information sought are attached at Annes-I&II.

Details of Appellate Authority, as per the provisions of RTI Act, 2005 is as under

Shri B. Mishra
Executive Director (CP & IT) & Appellate Authority,
Corporate Centre, Power Grid Corporation of India Limited,
"Saudamini", Plot No. 2, Sector-29,
Gurgaon – 122007, Haryana

Thanking You,

भवदीय,

(सुधीर मित्तल)

महाप्रबंधक(के.आ.) एवंके.लो.स्.अधिकारी



# पावर ग्रिड कारपोरेशन आफ इंडिया लिमिटेड केन्द्रीय कार्यालय

पावरग्रिः

CC/D(Proj)/Vigilance/2014

08.10.2014

### CIRCULAR

Sub: Irregularities/lapses observed during Vigilance Inspection

Through an inspection conducted by Vigilance Department, it has come to notice that, in one of the case, provisional taking over certificate (Operational Acceptance Certificate) was issued by site officials of POWERGRID without proper inspection of transmission line such as existence of Copper Bonds, Vibration Dampers/Spacer Dampers, tightening of bolts & nuts on sample basis and without checking for missing members, existence of trees in electrical clearance zone, ground clearance etc, leading to collapse of towers during Defect Liability Period.

It is advised to all concerned that the aforesaid lapses are to be avoided in order to prevent deficiencies and such type of occurrences in future. The Commissioning Team shall test check at least 5% of total number of spans on random basis in line Para C2.15.4 of WPPP. The various check points for inspection by the Commissioning Team shall include installation of Copper Bonds, Vibration dampers/Spacer dampers, tightening of bolts & nuts on sample basis and shall check for missing members, existence of trees in electrical clearance zone, ground clearance etc. and report the same to Construction-in-Charge for timely action.

Further, pre-commissioning procedures & formats for transmission lines shall be strictly complied with by the site officials before taking over from construction to O&M stage.

IS that

Copy to: All Regional EDs

Copy for kind information: CVO

गोपनीय

## पावर ग्रिड कारपोरेशन ऑफ इण्डिया लिमिटेड (केन्द्रीय सतर्कता विभाग) अन्तर कार्यालय जापन

प्रेषक: मुख्य सतर्कता अधिकारी

सेवा में: निदेशक (परियोजना)

संदर्भ: के.का:सतर्कता:2014 // 4 कि

दिनॉक: 20 अक्टूबर, 2014

विषय: Irregularities/lapses observed during Vigilance Inspection.

This has reference to your circular No: CC/D(Proj)/Vigilance/2014 dated 08.10.2014 on the subject noted above. In this regard it is requested that you may send us the action taken report on the points mentioned in this circular.

Further, as you are aware that there are some instances of submitting forged test certificates by the executing agencies. To obviate such instances, it is suggested that all test laboratories approved by NABL and recommended by POWERGRID may be put in the website of the Corporation. This will bring transparency, integrity and efficiency in the POWERGRID. It is also suggested that the letters requesting test of material etc. may be handed over to the designated laboratories by POWERGRID officials only with a request that reports may be sent directly to POWERGRID only. This will ensure authenticity of the test reports.

Action taken in this matter may be intimated to this office.

(परवैज हयात)