

पावर ग्रिड कारपोरेशन ऑफ इंडिया लिमिटेड

(भारत सरकार का उद्यम)

POWER GRID CORPORATION OF INDIA LIMITED

(A Government of India Enterprise)



पावरग्रिड

केन्द्रीय कार्यालय : "सौदामिनी" प्लॉट सं. 2, सैक्टर-29, गुडगाँव-122 001, हरियाणा
फोन : 0124-2571700-719, फैक्स : 0124-2571760, 2571761 तार 'नेटग्रिड'
Corporate Office : "Saudamini" Plot No. 2, Sector-29, Gurgaon-122 001. Haryana
Tel. : 0124-2571700-719, Fax : 0124-2571760, 0124-2571761 Gram : 'NATGRID'

संदर्भ संख्या / Ref. No.

C/CP/RTI/2015/199

Date: 19th February 2015

Shri Ramashanker Gupta
C/o Gupta Agency
Infront of Panna Loud Speakers
Dharamshala Bazar
Gorakhpur-273001

Sub: **Information under Right to Information Act, 2005.**

Dear Mr. Gupta,

This has reference to your RTI request dated 30th January 2015 seeking information under RTI Act, 2005.

The information sought is attached at **Annex-I**.

Details of Appellate Authority, as per the provisions of RTI Act, 2005 is as under:

Shri B. Mishra
Executive Director (CP & IT) & Appellate Authority,
Corporate Centre, Power Grid Corporation of India Limited,
"Saudamini", Plot No. 2, Sector-29 Gurgaon – 122007, Haryana.

Thanking You,

भवदीय,

(सुधीर मित्रल)

महाप्रबंधक(के.आ.) एवं के.तो.सू. अधिकारी

Information sought by Sh. Manishanker Gupta, Gorakhpur
under the RTI Act, 2005.

1) Central Electricity Authority Regulations for "Measures relating to Safety and Electric Supply, 2010" inter-alia stipulate under clause no. 61, the vertical and horizontal clearance of an overhead line conductor passing above or adjacent to any building or part of a building. This document is available in public domain and can be accessed from the CEA's web site/ office.

2) Double circuit transmission line is a transmission line which carries two circuits each having 3 phases.

Single circuit transmission line is a transmission line which carries one circuit having 3 phases.

For further information, Bureau of Indian Standard IS: 5613 may be referred. This document can be accessed from their office/ public domain website.