



पावर ग्रिड कोर्पोरेशन ऑफ इंडिया लिमिटेड

Power Grid Corporation of India Limited

सूचना का अधिकार अभिनियम 2005 के अंतर्गत केन्द्रीय लोक सूचना अधिकारी

Central Public Information Officer under the RTI Act, 2005

केन्द्रीय कार्यालय, 'सौदामिनी', प्लॉट नं.2, सेक्टर-29, गुडगांव, हरियाणा-122007

Corporate Centre, 'Saudamini', Plot No. 2, Sector-29, Gurgaon, Haryana-122007



CP/RTI/2016/318

Date: 5th May, 2016

Shri Jagdish Agarwal
Flat-G4, south Side Uday Kiran
House No.62, Masjid Moth Near Uday Park
Mother Dair, New Delhi-110049

Sub: Information under Right to Information Act, 2005 (Application No. 318 dated 06.03.2016.)

Dear Mr. Agarwal,

This has reference to your online RTI request dated 6th March, 2016, seeking information under RTI Act, 2005.


The information sought is attached at **Annex-I**.

First Appeal, if any, against the reply of CPIO may be made to the first appellate Authority within 30 days of the receipt of the reply of CPIO. Details of Appellate Authority at Corporate Centre, Gurgaon, under RTI Act, 2005 is as below:

Shri B. Mishra
Executive Director (CP & IT) & Appellate Authority
Corporate Centre, Power Grid Corporation of India Limited
"Saudamini", Plot No. 2, Sector-29, Gurgaon – 122007, Haryana.
Email ID: bmishra@powergridindia.com
Phone No. 0124-2571960

Thanking you,

भवदीय,



(सतीश कुमार जे.)

उप महाप्रबंधक (.आ.के) एवं के.लो.सू.अधिकारी

Phone No. 0124-2822746

Email ID: cpioccc@powergrid.co.in

ANNEX-1

Sub: RTI reply on technical specifications of thermo-vision camera used in substations.

This is in reference to information sought under RTI regarding Technical Specifications for Thermo vision camera used in Substation. In this regard, it is to inform you that Standard Technical Specifications for Thermo-vision Camera as per Control Document No : D-5-10-30-01-03 (Rev-03) (Document : NORMS AND TECHNICAL SPECIFICATIONS OF TESTING INSTRUMENTS (Volume-II) FOR SUBSTATIONS, REGIONAL & SPECIAL TESTING LABS) do specify the Measurement Range for Temperature as 0-250 deg C and not 2000 deg C as said in the letter.

0
21/21
2/5/16