



सूचना
का अधिकार

पावर ग्रिड कोर्पोरेशन ऑफ इंडिया लिमिटेड
Power Grid Corporation of India Limited
सूचना का अधिकार अभिनियम 2005 के अंतर्गत केन्द्रीय लोक सूचना अधिकारी
Central Public Information Officer under the RTI Act, 2005
केन्द्रीय कार्यालय, 'साँदामिनी', प्लॉट नं.2, सैक्टर-29, गुडगांव, हरियाणा-122007
Corporate Centre, 'Saudamini', Plot No. 2, Sector-29, Gurgaon, Haryana-
122007



पावरग्रिड

CP/RTI/2016/345

Date: 9th June, 2016

Shri Ram Dass Dange
House No. 1991, Sector 4
Urban Estate Gurgaon, Haryana-122006

Sub: Information under Right to Information Act, 2005 (Application No. 345 dated 25.03.2016.)

Dear Mr. Dange,

This has reference to your RTI request dated 25th March, 2016 (received on 29th March, 2016), seeking information under RTI Act, 2005.

The information sought is attached at **Annex-A**, after due application of severability clause, i.e ,Section 10 (1) of the RTI Act, 2005.

Since, the compilation of the information took some time and therefore information sought couldn't be provided within 30 days of period. Accordingly, no fee is being levied towards photocopy charges. The delay was unintentional and inconvenience caused is regretted, please.

First Appeal, if any, against the reply of CPIO may be made to the first appellate Authority within 30 days of the receipt of the reply of CPIO. Details of Appellate Authority at Corporate Centre, Gurgaon, under RTI Act, 2005 is as below:

Shri B. Mishra
Executive Director (CP & IT) & Appellate Authority
Corporate Centre, Power Grid Corporation of India Limited
"Saudamini", Plot No. 2, Sector-29, Gurgaon – 122007, Haryana.
Email ID: bmishra@powergridindia.com
Phone No. 0124-2571960

Thanking you,

भवदीय,

सतीश कुमार जे.

(सतीश कुमार जे.)

उप महाप्रबंधक (के.आ.) एवं के.लो.सू.अधिकारी

Phone No. 0124-2822746

Email ID: cpioccc@powergrid.co.in

संदर्भ संख्या सू का अ अ , 05/आंतरिक- 15/ 345/38 dated 30.03.2016

Point wise reply of the queries pertaining to Corporate Contract Services Department is given below:

Query no. 1 (at sl. no. 5 (c)) :

Amendment copy against said Tender

Reply:

Copy of the said Amendments is enclosed (Total 3 pages).

Query no. 2 (at sl. no. 5 (d)) :

Name of Participant

Reply:

The subject package was awarded on 10.12.2014 & 07.01.2015 to APAR & GUPTA Respectively. Name of all Bidders/Participants are uploaded in 'Monthwise Awarded Contract Detail' on POWERGRID's website i.e. www.powergridindia.com.

Query no. 3 (at sl. no. 5 (e)) :

Name of qualified Participants

Reply:

Same as reply to query no. 2 above.

Query no. 4 (at sl. no. 5 (f)) :

Award of LOI

Reply:

Notification of Award dated 10.12.2014 & 07.01.2015 was issued to M/s. Apar Industries Ltd, Vadodara and M/s Gupta Power Infrastructure Ltd, Ghaziabad. Copy of Notification of Award is part of Vol-A of Contract Agreement referred at reply to query no. 5 below.

Query no. 5 (at sl. no. 5 (g)) :

Copy of detail agreement

Reply:

Contract Agreement consists three Volumes viz. A, B & C. Volume-B of Contract Agreement includes Tender/Bidding Documents, which were uploaded on POWERGRID's website, i.e. www.powergridindia.com along with all the Tender/Bidding Documents (Tender ID: 6517), requestor may download the same from the website. Further, Volume-A and Volume -C of the Contract Agreement may contain some third party (i.e. Contractor) information for

Pr
KIRAN
Engineer/CS

which consent is required from the Contractor to provide the same. Accordingly, Contractor is being requested for permission to provide such documents. (Details of Volume A and C enclosed) @

Query no. 6 (at sl. no. 5 (h)) :

Supply status as on date

Reply:

The said query ~~does not~~ pertain to CS Deptt. (Supply Completed) @

ASH

KIRAN

Engineer (CS).

ANNEXURE-II

Issuance of Amendment-I to bidding documents for Supply of High Temperature Low Sag (HTLS) Conductor for Neyveli TS-II to Neyveli TS-I expansion 400kV link (one circuit only of D/C tower). under Transmission System associated with Contingency Plan for evacuation of Power from ILFS (2x600 MW); Specification No.: CC-CS/445-SR2/CD-2393/3/G5

S.No	Clause No	Existing provision	Amended Provision
1	Form No-6, Performance Security Form, Section - VI, Vol.-I of the Bidding Documents	<p>.....</p> <p>Contract No.....</p> <p>.....[Name of Contract].....</p> <p>.....</p> <p>We refer to the Contract ("the Contract") signed on(insert date of the Contract)..... between you and M/s (Name of Supplier), having.....</p>	<p>NOA/Contract No.....</p> <p>.....[Name of Contract].....</p> <p>.....</p> <p>We refer to the Contract ("the Contract") signed on(insert date of the Contract)..... between you and M/s (Name of Supplier),</p> <p>(or)</p> <p>vide notification of award issued on (insert date of the notification of award)....by you to M/s (Name of Supplier),</p> <p>having.....</p>

Amendment-II to HTLS Conductor Package for Supply of High Temperature Low Sag (HTLS) Conductor for Neyveli TS-II to Neyveli TS-I expansion 400kV link (one circuit only of D/C tower) under Transmission system associated with Contingency Plan for evacuation of Power from ILFS; Specification No : CC-CS/445-SR2/CD-2393/3/G5

SL. NO.	CLAUSE REF.	EXISTING PROVISION	AMENDED PROVISION																								
1	Clause No.- 1.2.1, Section-II, Volume II	Maximum permissible Conductor sag for 400m span at steady state conductor temperature and nil wind corresponding to 50 Hz alternating current of 1228 Amperes per sub conductor under ambient conditions specified above = 12.972 m	Maximum permissible Conductor sag for 400m span at steady state conductor temperature and nil wind corresponding to 50 Hz alternating current of 1228 Amperes per sub conductor under ambient conditions specified above = 12.87 m																								
2	Clause No.- 1.4.1, Section-II, Volume II	<table border="1"> <thead> <tr> <th>Particulars</th> <th>Limiting value</th> </tr> </thead> <tbody> <tr> <td>Tension at every day condition (32°C, no wind)</td> <td>Not exceeding 25% of UTS of proposed conductor</td> </tr> <tr> <td>Sag at maximum continuous operating temp (corresponding to 1228 amperes per subconductor and ambient conditions specified at 1.2.1)</td> <td>≤12.972 meters</td> </tr> </tbody> </table> <p>Tension at following wind pressure:-</p> <table border="1"> <tbody> <tr> <td>i) Tension at 32 deg C, full wind (52 kg/m²)</td> <td>≤ 4278 kg & not exceeding 50% of UTS of proposed conductor</td> </tr> <tr> <td>ii) Tension at 0 deg C, 2/3 wind pressure (35 kg/m²)</td> <td>≤ 4477 kg & not exceeding 50% of UTS of proposed conductor</td> </tr> </tbody> </table>	Particulars	Limiting value	Tension at every day condition (32°C, no wind)	Not exceeding 25% of UTS of proposed conductor	Sag at maximum continuous operating temp (corresponding to 1228 amperes per subconductor and ambient conditions specified at 1.2.1)	≤12.972 meters	i) Tension at 32 deg C, full wind (52 kg/m ²)	≤ 4278 kg & not exceeding 50% of UTS of proposed conductor	ii) Tension at 0 deg C, 2/3 wind pressure (35 kg/m ²)	≤ 4477 kg & not exceeding 50% of UTS of proposed conductor	<table border="1"> <thead> <tr> <th>Particulars</th> <th>Limiting value</th> </tr> </thead> <tbody> <tr> <td>Tension at every day condition (32°C, no wind)</td> <td>Not exceeding 25% of UTS of proposed conductor</td> </tr> <tr> <td>Sag at maximum continuous operating temp (corresponding to 1228 amperes per subconductor and ambient conditions specified at 1.2.1)</td> <td>≤12.87 meters</td> </tr> </tbody> </table> <p>Tensions under Condition-I:-</p> <table border="1"> <tbody> <tr> <td>i) Tension at 32 deg C, full wind (45 kg/m²)</td> <td>≤ 4278 kg & not exceeding 50% of UTS of proposed conductor</td> </tr> <tr> <td>ii) Tension at 0 deg C, 2/3 wind pressure (30 kg/m²)</td> <td>≤ 4480 kg & not exceeding 50% of UTS of proposed conductor</td> </tr> </tbody> </table> <p>Tensions under Condition-II:-</p> <table border="1"> <tbody> <tr> <td>i) Tension at 32 deg C, full wind (181 kg/m²)</td> <td>≤ 8691 kg & not exceeding 70% of UTS of proposed conductor</td> </tr> <tr> <td>ii) Tension at 0 deg C, 36% full wind pressure (65 kg/m²)</td> <td>≤ 5438 kg & not exceeding 70% of UTS of proposed conductor</td> </tr> </tbody> </table>	Particulars	Limiting value	Tension at every day condition (32°C, no wind)	Not exceeding 25% of UTS of proposed conductor	Sag at maximum continuous operating temp (corresponding to 1228 amperes per subconductor and ambient conditions specified at 1.2.1)	≤12.87 meters	i) Tension at 32 deg C, full wind (45 kg/m ²)	≤ 4278 kg & not exceeding 50% of UTS of proposed conductor	ii) Tension at 0 deg C, 2/3 wind pressure (30 kg/m ²)	≤ 4480 kg & not exceeding 50% of UTS of proposed conductor	i) Tension at 32 deg C, full wind (181 kg/m ²)	≤ 8691 kg & not exceeding 70% of UTS of proposed conductor	ii) Tension at 0 deg C, 36% full wind pressure (65 kg/m ²)	≤ 5438 kg & not exceeding 70% of UTS of proposed conductor
Particulars	Limiting value																										
Tension at every day condition (32°C, no wind)	Not exceeding 25% of UTS of proposed conductor																										
Sag at maximum continuous operating temp (corresponding to 1228 amperes per subconductor and ambient conditions specified at 1.2.1)	≤12.972 meters																										
i) Tension at 32 deg C, full wind (52 kg/m ²)	≤ 4278 kg & not exceeding 50% of UTS of proposed conductor																										
ii) Tension at 0 deg C, 2/3 wind pressure (35 kg/m ²)	≤ 4477 kg & not exceeding 50% of UTS of proposed conductor																										
Particulars	Limiting value																										
Tension at every day condition (32°C, no wind)	Not exceeding 25% of UTS of proposed conductor																										
Sag at maximum continuous operating temp (corresponding to 1228 amperes per subconductor and ambient conditions specified at 1.2.1)	≤12.87 meters																										
i) Tension at 32 deg C, full wind (45 kg/m ²)	≤ 4278 kg & not exceeding 50% of UTS of proposed conductor																										
ii) Tension at 0 deg C, 2/3 wind pressure (30 kg/m ²)	≤ 4480 kg & not exceeding 50% of UTS of proposed conductor																										
i) Tension at 32 deg C, full wind (181 kg/m ²)	≤ 8691 kg & not exceeding 70% of UTS of proposed conductor																										
ii) Tension at 0 deg C, 36% full wind pressure (65 kg/m ²)	≤ 5438 kg & not exceeding 70% of UTS of proposed conductor																										

SL. NO.	CLAUSE REF.	EXISTING PROVISION	AMENDED PROVISION																
		Volume-II, Technical Specification: Document Code: DC-2117-13116, May 2014																	
3..	Technica l Data Sheets schedule -1 HTLS CONDU CTOR page 5 of 5 (S.N- 7.19.3)Volume II	<table border="1"> <thead> <tr> <th>Description</th> <th>unit</th> </tr> </thead> <tbody> <tr> <td>i) Tension at 32 deg. C & full wind for following wind pressure : Wind Pressure : 52 kg/m²</td> <td>kg</td> </tr> <tr> <td>ii) Tension at 0 deg. C, 2/3 wind pressure : 35 kg/m²</td> <td>kg</td> </tr> </tbody> </table>	Description	unit	i) Tension at 32 deg. C & full wind for following wind pressure : Wind Pressure : 52 kg/m ²	kg	ii) Tension at 0 deg. C, 2/3 wind pressure : 35 kg/m ²	kg	<table border="1"> <thead> <tr> <th>Description</th> <th>unit</th> </tr> </thead> <tbody> <tr> <td>Tensions under Condition-I:- i) Tension at 32 deg. C & full wind pressure (45 kg/m²)</td> <td>kg</td> </tr> <tr> <td>ii) Tension at 0 deg C, 2/3 wind pressure (30 kg/m²)</td> <td>kg</td> </tr> <tr> <td>Tensions under Condition-II:- i) Tension at 32 deg C, full wind (181 kg/m²)</td> <td>kg</td> </tr> <tr> <td>ii) Tension at 0 deg C, 36% full wind pressure (65 kg/m²)</td> <td>kg</td> </tr> </tbody> </table>	Description	unit	Tensions under Condition-I:- i) Tension at 32 deg. C & full wind pressure (45 kg/m ²)	kg	ii) Tension at 0 deg C, 2/3 wind pressure (30 kg/m ²)	kg	Tensions under Condition-II:- i) Tension at 32 deg C, full wind (181 kg/m ²)	kg	ii) Tension at 0 deg C, 36% full wind pressure (65 kg/m ²)	kg
Description	unit																		
i) Tension at 32 deg. C & full wind for following wind pressure : Wind Pressure : 52 kg/m ²	kg																		
ii) Tension at 0 deg. C, 2/3 wind pressure : 35 kg/m ²	kg																		
Description	unit																		
Tensions under Condition-I:- i) Tension at 32 deg. C & full wind pressure (45 kg/m ²)	kg																		
ii) Tension at 0 deg C, 2/3 wind pressure (30 kg/m ²)	kg																		
Tensions under Condition-II:- i) Tension at 32 deg C, full wind (181 kg/m ²)	kg																		
ii) Tension at 0 deg C, 36% full wind pressure (65 kg/m ²)	kg																		

A. Contract Agreement No.:

CC-CS/445-SR2/CD-2393/3/G5/CA/5139 dtd.17.12.2014 awarded to M/s Apar Industries Ltd, Vadodara.

1.0 APAR vide their letter dtd.05.05.2016 have consented to disclose the information in CAs except price break-up of each individual item in Volume-A of the CA, design parameters of conductor & hardware fittings, RAC calculation, current carrying capacity calculation and sag tension chart submitted in their bid forming part of Volume-C. Accordingly, copy of Contract Agreement except the above said information is being given as per the following details:

- (i) Volume-A of Contract Agreement:
(except page nos: 18, 22 to 27)
- (ii) Volume-C of Contract Agreement:
(except page nos. 08 to 36, 48, 54-55)

B. Contract Agreement No.: CC-CS/445-SR2/CD-2393/3/G5/CA/5173 dtd.27.01.2015 awarded to M/s Gupta Power Infrastructure Limited, Kolkata.

1.0 GUPTA vide their letter dtd.23.05.2016 (copy enclosed) have consented to disclose the information in CAs except page no 22-27 of Volume A and Page no 1-49 of Volume -C of the CA. Accordingly, copy of Contract Agreement except the above said information is being given as per the following details:

- (i) Volume-A of Contract Agreement:
(except page nos: 22 to 27)
- (ii) Volume-C of Contract Agreement:
(except page nos. 1 to 49)



KG
Khan
Engineer (CS)