



पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड
Power Grid Corporation of India Limited
सूचना का अधिकार अभिनियम 2005 के अंतर्गत केन्द्रीय लोक सूचना अधिकारी
Central Public Information Officer under the RTI Act, 2005
केन्द्रीय कार्यालय, 'सादामिनी', प्लॉट नं.2, सेक्टर-29, गुडगांव, हरियाणा-122007
Corporate Centre, 'Saudamini', Plot No. 2, Sector-29, Gurgaon, Haryana-122007



CP/RTI/2016/203

Date: 29th September, 2016

Shri Thirumalai Dasan K.,
Flat D 15-14,
K-G Signature City,
200 Ft Maduravoyal By-pass,
Mogappair, Chennai.
Tamil Nadu-600095

Sub: Information under Right to Information Act, 2005.

Dear Mr Dasan,

This has reference to your online RTI request dated 13th September, 2016, seeking information under RTI Act, 2005.

The information sought is attached at **Annex-I**.

First Appeal, if any, against the reply of CPIO may be made to the first appellate Authority within 30 days of the receipt of the reply of CPIO. Details of Appellate Authority at Corporate Centre, Gurgaon, under RTI Act, 2005 is as below:

Shri S. K. Sharma
Executive Director (CP) & Appellate Authority
Corporate Centre, Power Grid Corporation of India Limited
"Saudamini", Plot No. 2, Sector-29, Gurgaon – 122007, Haryana.
Email ID: s.k.sharma@powergridindia.com
Phone No. 0124-2571960

Thanking you,

भवदीय,

(अजय होलानी)

अपर महाप्रबंधक (के.आ.) एवं के.लो.सू.अधिकारी

Email ID: cpio.cc@powergrid.co.in

Annex I

Draft RTI Reply

Ref: Request dated 13.09.2016 from Shri K.Thirumali Dasan, Chennai

Sub: INFORMATION SOUGHT UNDER RTI ACT 2005

SL.No	Information Sought about	Reply
1)	What are all the guidelines stipulated, if such HT lines are laid inside the Residential complex.	The guidelines given in "CEA (Measures relating to Safety & Electricity Supply) Regulations, 2010" (The same can be downloaded from the website of Central Electricity Authority (www.cea.nic.in)) and the electrical clearances specified in "Manual on Transmission Lines of Central Board of Irrigation & Power" (The same can be purchased online from Central Board of Irrigation & Power (www.cbip.org)) are followed by POWERGRID while constructing HT Lines. The builders of Residential Complexes are also required to adhere to the above statutory electrical clearances when constructing complexes near HT Lines.
2)	What are all the guide lines to be followed by the builder.	
3)	Is there any references made to National building code.	
4)	Can car parking, Two wheeler parking and open theatre under HT Lines allowed	
5)	If yes, What are all the conditions to be followed.	

G. Nallathambi
(I.NALLATHAMBY)

DGM(AM/SAFETY)/CC

26/9/2016

