


पावर ग्रिड कोर्पोरशन ऑफ इंडिया लिमिटेड

Power Grid Corporation of India Limited



Corporate Centre, 'Saudamini', Plot No. 2, Sector-29, Gurgaon, Haryana-122007

CP/RTI/2016/656

Date: 9th March, 2017

Shri Sheshadri N. S/o Shri Sreenivasulu N. 1-270-1, Opp. Court Road Kadiri-515591, Andhra Pradesh

Sub: Information under Right to Information Act, 2005.

Dear Sir,

This has reference to your RTI request dated 10th February, 2017 seeking information under RTI Act. 2005.

The information sought is attached as Annexure-I.

First Appeal, if any, against the reply of CPIO may be made to the first appellate Authority within 30 days of the receipt of the reply of CPIO. Details of Appellate Authority at Corporate Centre, Gurgaon, under RTI Act, 2005 is as below:

Shri Ashwani Jain

Executive Director (CMG) & Appellate Authority

Corporate Centre, Power Grid Corporation of India Limited

"Saudamini", Plot No. 2, Sector-29, Gurgaon – 122007, Haryana.

Email ID: aj@powergridindia.com

Phone No. 0124-2571962

Thanking you,

भवदीय,

अपर महाप्रबंधक (के.आ.) एवं के.लो.स्.अधिकारी

Email ID: cpio.cc@powergrid.co.in

Information sought by Sh. Sheshadri N of Kadir, Andhra Pradesh under the RTI Act, 2005.

The information sought by the requester is general in nature and do not pertain specifically to any transmission line of POWERGRID. However, following may be noted:

There is no restriction of 400kV line coming into town which is already established or under development provided adequate electrical clearances are maintained and other safety regulations are followed.

It may be informed that the transmission lines in the country are constructed as per the Central Electricity Authority's Regulations 2010/2011 viz. "Technical Standards for Construction of Electrical Plants and Electric Lines", "Measures relating to Safety and Electric Supply" & "Safety requirements for Construction, Operation and Maintenance of Electrical Plants and Electric Lines" as well as Bureau of Indian Standard IS: 5613. These documents are available in public domain and can be accessed from the web sites/ offices of CEA & BIS. These regulations provide the parameters for various voltage levels of the transmission lines.

CEA's Regulations for "Measures relating to Safety and Electric Supply, 2010" inter-alia stipulate under clause no. 61, the required minimum electrical clearances in case of an overhead line conductor passing above or adjacent to any building or part of a building.