



पावर ग्रिड कोर्पोरेशन ऑफ इंडिया लिमिटेड
Power Grid Corporation of India Limited
सूचना का अधिकार अभिनियम 2005 के अंतर्गत केन्द्रीय लोक सूचना अधिकारी
Central Public Information Officer under the RTI Act, 2005
केन्द्रीय कार्यालय, 'सौदामिनी', प्लॉट नं.2, सैक्टर-29, गुडगांव, हरियाणा-122007
Corporate Centre, 'Saudamini', Plot No. 2, Sector-29, Gurgaon, Haryana-122007



CP/RTI/2017/220

Date: 12th September, 2017

Shri Sachin,
139, Mazid ganj,
Najibabad – 246 763
Uttar Pradesh

Sub: Information under Right to Information Act, 2005.

Dear Sir,

This has reference to your online RTI request dated 24th August, 2017 seeking information under RTI Act, 2005.


The information sought is attached at **Annexure-I**.

First Appeal, if any, against the reply of CPIO may be made to the first appellate Authority within 30 days of the receipt of the reply of CPIO. Details of Appellate Authority at Corporate Centre, Gurgaon, under RTI Act, 2005 is as below:

Shri Sanjeev Singh,
Executive Director (CMG) & Appellate Authority
Corporate Centre, Power Grid Corporation of India Limited
"Saudamini", Plot No. 2, Sector-29, Gurgaon – 122007, Haryana.
Email ID: sanjeev@powergridindia.com
Phone No. 0124-2571962

Thanking you,

भवदीय,


(अजय होलानी)

अपर महाप्रबंधक (के.आ.) एवं के.लो.सू.अधिकारी

Email ID: cpio.cc@powergrid.co.in

Information sought by Sh. Sachin, Najibabad, UP
under the RTI Act, 2005.

The information sought by the requester is general in nature and do not pertain specifically to any transmission line of POWERGRID. However, following may be noted:

CEA's Regulations for "Measures relating to Safety and Electric Supply, 2010" inter-alia stipulate under clause no. 61, that an overhead line shall not cross over an existing building as far as possible and no building shall be constructed under an existing overhead line. Further, under the subject clause, required minimum vertical and horizontal clearances of an overhead line conductor (under maximum sag & swing condition) passing above or adjacent to any building or part of a building are also stipulated. The minimum vertical and horizontal electrical clearances of overhead conductor under maximum sag & swing condition for 400KV line as per clause no. 61, works out to be 7.3m and 5.6m

मनीष