



पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड
Power Grid Corporation of India Limited
सूचना का अधिकार अभिनियम 2005 के अंतर्गत केन्द्रीय लोक सूचना अधिकारी
Central Public Information Officer under the RTI Act, 2005
केन्द्रीय कार्यालय, 'सौदामिनी', प्लॉट नं.2, सेक्टर-29, गुडगांव, हरियाणा-122007
Corporate Centre, 'Saudamini', Plot No. 2, Sector-29, Gurgaon, Haryana-122007



CP/RTI/2017/290

Date: 31st October, 2017

Shri Raja,
29, Chandreshwar road,
Rishikesh – 249 201
Uttarakhand

Sub: Information under Right to Information Act, 2005.

Dear Sir,

This has reference to your online RTI request dated 8th October, 2017 for providing information under RTI Act, 2005.


Available information is attached at **Annexure-I**.

First Appeal, if any, against the reply of CPIO may be made to the first appellate Authority within 30 days of the receipt of the reply of CPIO. Details of Appellate Authority at Corporate Centre, Gurgaon, under RTI Act, 2005 is as below:

Shri Sanjeev Singh,
Executive Director (CMG) & Appellate Authority
Corporate Centre, Power Grid Corporation of India Limited
"Saudamini", Plot No. 2, Sector-29, Gurgaon – 122007, Haryana.
Email ID: sanjeev@powergridindia.com
Phone No. 0124-2571962

Thanking you,

भवदीय,


(अजय होलानी) 31/10

अपर महाप्रबंधक (के.आ.) एवं के.लो.सू.अधिकारी

Email ID: cpio.cc@powergrid.co.in

Attach: As above

Information sought by Sh. Raja

under the RTI Act, 2005.

The information sought by the requester is general in nature and do not pertain specifically to any transmission line of POWERGRID. However, following may be noted:

As per Central Electricity Authority's Regulations viz. "Measures relating to Safety and Electric Supply, 2010", Clause no. 61, an overhead line shall not cross over an existing building as far as possible and no building shall be constructed under an existing overhead line. Further, in case of an overhead line conductor passing above or adjacent to any building or part of a building, the minimum electrical clearances are stipulated.

For 765 kV transmission line, the minimum vertical clearance of overhead line conductor under maximum sag is 10.6 m and the minimum horizontal clearance of overhead line conductor under swing condition is 8.9 m.

मातृ