


## पावर ग्रिड कोर्पोरशन ऑफ इंडिया लिमिटेड

Power Grid Corporation of India Limited



Corporate Centre, 'Saudamini', Plot No. 2, Sector-29, Gurgaon, Haryana-122007

पावरग्रिड

CP/RTI/2017/479

Date: 24th January, 2018

Shri Vijay Wadettiwar, MLA & Former State Minister for Energy, Govt. of Maharashtra Kamlai Niwas, Ramdaspeth, Nagpur – 440 010

Sub: Information under Right to Information Act, 2005.

Sir,

This has reference to your RTI request Ref. Nos. VIP/VW/6008/2017 dated 18<sup>th</sup> November, 2017 forwarded by MOP through online RTI portal on 27<sup>th</sup> December, 2017 and VIP/VW/6009/2017 forwarded by CEA vide letter dated 18<sup>th</sup> November, 2017 for providing information under RTI Act, 2005.

The desired information is attached at Annexure-I & II.

First Appeal, if any, against the reply of CPIO may be made to the first appellate Authority within 30 days of the receipt of the reply of CPIO. Details of Appellate Authority at Corporate Centre, Gurgaon, under RTI Act, 2005 is as below:

Shri Sanjeev Singh,
Executive Director (CMG) & Appellate Authority
Corporate Centre, Power Grid Corporation of India Limited
"Saudamini", Plot No. 2, Sector-29, Gurgaon – 122007, Haryana.
Email ID: <a href="mailto:sanjeev@powergridindia.com">sanjeev@powergridindia.com</a>
Phone No. 0124-2571962

Thanking you,

भवदीय,

(अजय होलानी)

अपर महाप्रबंधक (के.आ.) एवं के.लो.स्.अधिकारी Email ID: cpio.cc@powergrid.co.in

- 1. Kindly provide advice/ suggestion and remedies by your office in view of the recent fire incidence at M/s NTPC, Unchahar Thermal Power Station, Dist. Raebareli: Reply -Not applicable to POWERGRID.
- Kindly provide advice/ suggestion on recent Reactor fire 110MVAR 765/400kV fire at 765/400kV Substation of PGCIL at Deoli, Wardha:
   Reply- In the fire that occurred in the 110 MVAR, 765 kV reactor at Wardha S/S of POWERGRID on 12.01.17, the fire protection system had operated as per scheme.
- 3. Kindly provide the advise/ suggestion on various major Transformer fire incidence in India, causing loss of human life, limb etc. and several thousand of crores as revenue loss:
  - **Reply-** Till date there is no fire incidence in the transformer/ reactors of POWERGRID causing loss of human life, limb etc.
- Kindly provide me the role of Ministry of Power to advise Circulars, Directives etc. to these organization or Government of India: Reply-Not applicable to POWERGRID.
- 5. Kindly provide me the precautionary measures, directives/ communication to avoid such type of incidence in future also share the communication if any, in this regard to me:

**Reply-**POWERGRID already provides the following fire protection system at all stations of voltage class 132 kV or above:

- a. Hydrant System
- b. High Velocity Water (H.V.W) Spray System
- c. Fire Detection and alarm System
- d. Portable Fire Extinguishers
- e. Wheel/ Trolley mounted Fire Extinguishers

All the equipment used complies with the Indian Standards as well as TAC/ NFPA guide line.

Ref. Nos. VIP/VW/6009/2017 dated 18th November, 2017

## Question NO. 4

Kindly provide me the role of NDRF to advise to these organization or Government of India.

## Answer:

Not applicable to POWERGRID.