



पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड

Power Grid Corporation of India Limited

सूचना का अधिकार अभिनियम 2005 के अंतर्गत केन्द्रीय लोक सूचना अधिकारी

Central Public Information Officer under the RTI Act, 2005

केन्द्रीय कार्यालय, 'सौदामिनी', प्लॉट नं.2, सैक्टर-29, गुडगांव, हरियाणा-122007

Corporate Centre, 'Saudamini', Plot No. 2, Sector-29, Gurgaon, Haryana-122007



CP/RTI/2018/320

Date: 17th September, 2018

Shri Anil K Kataria,
B3/1 Powergrid Township,
765/400 kV Substation,
Village – Adupura,
P.O: Roura Jhansi Road,
Gwalior – 475 001

Sub: Information under Right to Information Act, 2005.

Dear Sir,

This has reference to your online RTI request dated 15th August, 2018 for providing information under RTI Act, 2005. Point wise reply to the queries are given below:

Point No. 1

Waist level height of transmission line towers varies for different types of towers depending upon the tower design based on voltage level, wind zone, electrical clearances, angle of deviation, configuration/type of tower and extensions used. For 765 kV S/C wind zone-IV transmission lines, the waist level of Delta & Horizontal configuration towers of normal height in POWERGRID is typically in the range of 20m – 35m & 10m -20m respectively.

Point No. 2 to 6

Available information is attached at **Annexure-I**.

First Appeal, if any, against the reply of CPIO may be made to the first appellate Authority within 30 days of the receipt of the reply of CPIO. Details of Appellate Authority at Corporate Centre, Gurgaon, under RTI Act, 2005 is as below:

Shri Sanjeev Singh,
Executive Director (CMG) & Appellate Authority
Corporate Centre, Power Grid Corporation of India Limited
"Saudamini", Plot No. 2, Sector-29, Gurgaon – 122007, Haryana.
Email ID: sanjeev@powergridindia.com
Phone No. 0124-2571962

Thanking you,

भवदीय,

(अजय होलानी)

अपर महाप्रबंधक (के.आ.) एवं के.लो.सू.अधिकारी

Email ID: cpio.cc@powergrid.co.in

Sl. No	RTI query	Reply
2	What nature of maintenance works can be carried out in live line conditions above waist level?	Works like as Tower Top Patrolling, Punctured Insulator Detection, and other hotline maintenance works can be carried out in live line condition above waist level.
3	Does POWERGRID permits its regular employee or engaged contractual labor to work above waist level in live line condition.	Powergrid does all routine maintenance works through regular employees only except in extraordinary conditions
4	Do permit to work is required for TLM staff for carrying out maintenance work in 765 kV tower for Delta and Horizontal configuration above waist level.	Yes
5	In case of permit to work is not issued, do message is being logged in respective control room for carrying out maintenance work in 765 kV tower for Delta and Horizontal configuration above waist level.	Yes
6	What system of issuing Permit to work is followed in POWERGRID , i.e, SAP generated or manually generated.	Permit to work is normally generated through SAP.

(मनोज कुमार सिंह)