

पावर ग्रिड कारपोरेशन ऑफ इंडिया लिमिटेड
(भारत सरकार का उद्यम)

POWER GRID CORPORATION OF INDIA LIMITED
(A Government of India Enterprise)



प्लॉट नं. - 4, युनिट - 41, निलाद्री विहार, चन्द्रसेखरपुर - 751021
दुरभाष : 0674 - 2720754
Plot. No. 4, Unit - 41, Niladri Vihar, Chandrasekharpur,
Bhubaneswar-751021, Tel: 0674-2720754

SPEED POST

Ref. No. -PGCIL/ODP/ENGG/RTI/ JEYPORE SS/M-4/ ३८४ Date : 07-06-2019

To,

Sh. J.C. Kohli,
Indian Generators Manufacturers' Association,
No-27, MCHS, BTM Layout'
Bangaluru-560076

Sub. : Information sought under RTI Act, 2005.

Sir,

This has reference to your RTI application dated 24.01.2019 forwarded by CPIO, ER-II, Kolkata & received on 07/05/2019 for disclosing the information relating to DG set supplied at Jeypore Substation only against query raised in your RTI application.

In this regard we would like to submit the information against your query, and enclosed at **Annexure-Jeypore DG Set**.


In case, if you are aggrieved with the aforementioned reply / information then you may prefer an appeal before the first appellate authority, the details of appellate authority is as under:

Executive Director (Odisha Projects), First Appellate Authority
Power Grid Corporation of India Ltd
Plot No.-4, Unit-41
Niladrivihar,
Chandrasekharpur,
Bhubaneswar-751021.

This is for your kind information please.

Thanking you,

Yours faithfully


(S.K. Mishra) 7/6/19

CPIO & Sr.GM/ENGG/BBSR

COPY TO : M.CPIO & Sr.GM (PESM), ER-II, Kolkata, 02. GM, Jeypore SIC

**RTI Query-wise information for DG Set supplied at Jeypore Substation
by M/s Fortune Impex, Bhubaneswar**

Annexure-Jeypore DG Set

Sl. No.	Query	Information Furnished
1	Copies of type test reports as mentioned in 1.3 & 1.4 of award letter dtd: 12.05.2015	Already provided by CPIO,ER-II, Kolkata
2	Information if supply has been received, accepted & commissioned.	DG Set already received at Jeypore Substation & Commissioned on dt.19.02.2016
3	Payment made (total) to the party	17,16,153/-
4	Any complaint during guarantee period.	NIL
5	Information if CPG furnished by contractor to PGCIL.	Yes
6	You have sent us Type Approval (TA) of engine. Please send TA of DG set and COP of engine and DG set valid on the date of dispatch of DG Sets.	Already provided by CPIO,ER-II, Kolkata
7	What is the ambient temp of the alternator as per nameplate of the alternator	40°C
8	Information if technical documents and drawing were submitted by vendor / manufacturer and approved by PGCIL. If so, copy of the same may be provided	Already provided by CPIO,ER-II, Kolkata
9	Information if there is any requirement manufacturing of DG set by approved vendor of PGCIL. If so, information if the manufacturer is PGCIL approved.	Approved vendor
10	Information if AMF panel supplied is inside Acoustic enclosure or separate.	Separately provided.
11	Information if commissioning checks were conducted as per cl 1.10 of TS of PGCIL. If so, a copy of the same may be provided.	Yes. Copy of MOM, Service & Commissioning report attached. Total 17 pages attached.

17/02/2016

17/02/2016