



पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड
Power Grid Corporation of India Limited
सूचना का अधिकार अभिनियम 2005 के अंतर्गत केन्द्रीय लोक सूचना अधिकारी
Central Public Information Officer under the RTI Act, 2005
केन्द्रीय कार्यालय, 'सौदामिनी', प्लॉट नं.2, सेक्टर-29, गुडगांव, हरियाणा-122007
Corporate Centre, 'Saudamini', Plot No. 2, Sector-29, Gurgaon, Haryana-122007



PGCIL/R/2019/50392

दिनांक: 23 September, 2019

Shri Akash Kumar Saini,

S/o Shri Narendra Kumar Saini, C/o Atar Singh Aata Chakki, Shivdaspur urf Teliwala Dhanauri
Roorkee, Pin:247667, Uttarakhand

विषय: सूचना का अधिकार अधिनियम, 2005 के तहत जानकारी।

महोदय / महोदया,

कृपया आर.टी.आई. अधिनियम, 2005 के तहत दिनांक 6 September, 2019 को प्रेषित अपने आर.टी.आई. अनुरोध का संदर्भ लें।

उपरोक्त पत्र में वांछित जानकारी अनुलग्नक-1 में संलग्न है।


यदि आप केन्द्रीय लोक सूचना अधिकारी के उत्तर से संतुष्ट न हो तो, केन्द्रीय लोक सूचना अधिकारी के उत्तर की प्राप्ति के 30 दिनों के भीतर पहले अपील प्राधिकारी के सम्मुख अपील की जा सकती है। आरटीआई अधिनियम, 2005 के तहत केन्द्रीय कार्यालय, गुडगांव में अपील प्राधिकारी का विवरण निम्नानुसार है:

श्री संजीव सिंह,

कार्यपालक निदेशक (सी एम जी) एवं अपील प्राधिकारी
केन्द्रीय कार्यालय, पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड,
"सौदामिनी", प्लॉट नंबर-2, सेक्टर-29, गुडगांव-122001, हरियाणा।
ईमेल आईडी: sanjeev@powergridindia.com
फोन नंबर: 0124-2571962

धन्यवाद,

भवदीय,


(जसबीर सिंह) 23/09/19

वरिष्ठ महाप्रबंधक (के. आ.) एवं के.लो.सू.अधिकारी

Email ID: cpio.cc@powergrid.co.in

Information sought under the RTI Act, 2005.

The information sought by you is general in nature and do not pertain specifically to any transmission line of POWERGRID. However, following may be informed:

1) Reply to Query 1, 3 & 4

The transmission lines in the country are constructed as per the Central Electricity Authority's Regulations 2010/2011 viz. "Technical Standards for Construction of Electrical Plants and Electric Lines", "Measures relating to Safety and Electric Supply" & "Safety requirements for Construction, Operation and Maintenance of Electrical Plants and Electric Lines" as well as Bureau of Indian Standard IS: 5613. These documents are available in public domain and can be accessed from the web sites/ offices of CEA (Central Electricity Authority) & BIS (Bureau of Indian Standards).

CEA's Regulations for "Measures relating to Safety and Electric Supply, 2010" inter-alia stipulate under clause no. 61, that an overhead line shall not cross over an existing building as far as possible and no building shall be constructed under an existing overhead line. Further, in case of an overhead line conductor passing above or adjacent to any building or part of a building, the minimum electrical clearances are stipulated.

2) Reply to Query 2

There are no specific restrictions under transmission line regulations/ standards on use of internet or mobile phones near transmission lines. However, further information on restriction, if any imposed by internet/ mobile companies may be sought by the requestor from concerned Telecom Utilities/ Ministries.

Links of websites are given below:

www.cea.nic.in and www.bis.gov.in

-----X-----

