

RTI REQUEST DETAILS

Registration No. : PGCIL/R/2019/50444	Date of Receipt : 07/10/2019
Type of Receipt : Online Receipt	Language of Request : English
Name : Srinivasa Rao	Gender : Male
Address : F3, Plot no 19, Srujana Apt, Bhagyanagar colony, Kukatpally, Pin:560072	
State : Andhra Pradesh	Country : India
Phone No. : +91-9676996564	Mobile No. : +91-9676996564
Email : gandham76@gmail.com	
Status(Rural/Urban) : Urban	Education Status :
Is Requester Below Poverty Line ? : No	Citizenship Status : Indian
Amount Paid : 10)	Mode of Payment : Payment Gateway
Request Pertains to :	

Information Sought : Hi Team,

As per POWERGRID SUSTAINABILITY REPORT 2015-17 Page no 64, separate procedures has defined in diagram for both transmission lines and Substations

Transmission line Construction
 Public Consultation for Screening, Assessment and Route/ Site finalization
 Consultation at individual and community level
 Resolution of issues raised during initial screening and walkover surveys
 Affected person(s) compensated as per provisions/ Issues Resolved

PGCIL follows below 11 public consultation techniques at different milestones of the project
 Project Coordination Committees
 Local planning visits
 Public Meetings
 Informal group meetings
 Site Visits
 Press releases, inviting comments
 Brochures, pamphlets
 Public Display
 Ombudsman or Representative
 Field offices
 Response to public enquiries

PGCIL has only followed Press releases, inviting comments method out of 11 techniques for below lines as per RTI request PGCIL/R/2019/50072 at line route alignment milestone of the project.

Please provide public consultation technique used at other milestone Screening and Assessment phase of the project as per diagram for transmission lines for below lines.

Vemagiri 2 to Chilakaluripeta 765kV D/c line with 240 MVAR switchable line reactor at both ends.

Chilakaluripeta to Cuddapah 765kV D/c line with 240 MVAR switchable line reactor at both ends.

Chilakaluripeta to Narsaraopeta 400kV (quad) D/c line.

Cuddapah to Madhugiri 400kV (quad) D/c line with 80 MVAR switchable