



पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड
Power Grid Corporation of India Limited
सूचना का अधिकार अभिनियम 2005 के अंतर्गत केन्द्रीय लोक सूचना अधिकारी
Central Public Information Officer under the RTI Act, 2005
केन्द्रीय कार्यालय, 'सौदामिनी', प्लॉट नं.2, सेक्टर-29, गुडगांव, हरियाणा-122007
Corporate Centre, 'Saudamini', Plot No. 2, Sector-29, Gurgaon, Haryana-122007



CIN : L40101DL1989GOI038121

PGCIL/R/2019/50497

दिनांक: 15 November, 2019

Shri Sivaprakash,

3/172, Thi Thi Thottam, Kaluveri Palayam,, Nathagovundanpalayam (PO), Palladam (TK), Tirupur (DT), Pin:641664,Tamilnadu

विषय: सूचना का अधिकार अधिनियम, 2005 के तहत जानकारी ।

महोदय / महोदया,

कृपया आर.टी.आई. अधिनियम, 2005 के तहत दिनांक 11 November, 2019 को प्रेषित अपने आर.टी.आई. अनुरोध का संदर्भ लें ।

उपरोक्त पत्र मे वांछित जानकारी अनुलग्नक-1 मे संलग्न है ।

यदि आप केन्द्रीय लोक सूचना अधिकारी के उत्तर से संतुष्ट न हो तो, केन्द्रीय लोक सूचना अधिकारी के उत्तर की प्राप्ति के 30 दिनों के भीतर पहले अपील प्राधिकारी के सम्मुख अपील की जा सकती है। आरटीआई अधिनियम, 2005 के तहत केन्द्रीय कार्यालय, गुडगांव में अपील प्राधिकारी का विवरण निम्नानुसार है:

श्री संजीव सिंह,

कार्यपालक निदेशक (सी एम जी) एवं अपील प्राधिकारी
केन्द्रीय कार्यालय, पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड,
"सौदामिनी", प्लॉट नंबर-2, सेक्टर-29, गुडगांव-122001, हरियाणा।
ईमेल आईडी: sanjeev@powergridindia.com
फोन नंबर: 0124-2571962

धन्यवाद,

भवदीय,

f/o
RP Singh
15/11/19

(जसबीर सिंह)

वरिष्ठ महाप्रबंधक (के. आ.) व के. लो. सू. अधिकारी

Email id: cpio.cc@powergrid.co.in

विषय: Information sought under RTI Act, 2005 by Shri Sivaprakash.

Point wise reply to RTI Query of Shri Sivaprakash is as given below:


1. Can we dig a borewell or an openwell under the HT line.

- Digging of a borewell or open well or raising any structure is governed by the provisions of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010, notified in Gazeette of India No. CEI/1/59/CEA/EI dtd. 20.09.2010. Regulation 61 provided details of the vertical and horizontal clearances to be maintained from high voltage lines for any building/structure and Regulation 63 provides for procedure for same. Therefore, if the borewell & open well meet the clearance requirement as stipulated in CEA notification it can be built subject to regulations 61 & 63 of the same notification.

2. As you already said that agriculture can be carried under the HT line if there is any problem in the line how will you work in the farmlands after cultivation. If there is any damage to the crops will Power Grid Corporation provide any compensation to the farmers or bare the whole loss.

- It is submitted that as a responsible corporate entity, POWERGRID always addresses all the social impacts associated with its projects during every stage of project cycle including Operations & Maintenance (O&M). As such in case any of our line requires repair due to any problems or even during routine maintenance exercises, for any damage to standing crops/trees, we pay full compensation for the same as per the assessment done by the Revenue Authorities.

----x----


15/11/2019