

Registered Post with Acknowledgement Due

Ref: SR-II: RTI: F-917:2019/ 2207

Date: 27th December, 2019

To

Shri P.Ajayakumar,
Kizhakkidathu,
Vathikulam, Thekkekkara Village,
Mavelikara - 690 107.
Alappuzha Distt.
Kerala

Sir,

Sub: Your RTI Appeal dated 08.12.2019 – reg.

This is with reference to your appeal dated 08/12/2019 under RTI Act, 2005 received at this office on 13/12/2019 seeking information as to which office of POWERGRID has the competency to issue NOC for a building falling under LOC.No.52,53 of 220 kV Kayamkulam-Eadamon Transmission Line.

Central Electricity Authority (Measures relating to Safety & Electric Supply) Regulations, 2010 which came into force Gazette Notified w.e.f.24.09.2010 framed by CEA in exercise of powers conferred by & under Section 177 of the Electricity Act, 2003 vide Regulation 60 & 61 prohibits construction of building under an existing overhead line. As such, POWERGRID has no authority to issue such "No Objection Certificate" for any building falling under the tip to tip corridor of the subject Transmission Line.

Thanking you,

Yours faithfully,



(S.RAVI)

Executive Director (SRTS-II)
Appellate Authority
e-mail : sr2edo@powergrid.co.in
Tel.No.: 080-23093701