

Ref. No. POWERGRID/NR-3/RTI/19-20/35

Date : 27.01.2020

To,
Ashok Kumar Kanchan (partner)
Ashoka Constructions
49, Baljati Well,
Old City, Bareilly-243005

Sub.: Regarding Information sought vide communication dated 27.12.2019 under RTI Act, 2005.

Sir,

This has reference to your RTI application, received at NR-III, RHQ, Lucknow on 30.12.2019. In this regard, information sought by you is as under:

S.No.	Information Sought	Information Provided
Name of Work :- Modification of existing 50 MVA Transformer foundation and construction of new spare foundation at Tanakpur (HEP) NHPC LOA No:-NR-III/5006000483/LOA/K00/770 dt 24.09.19		
01.	Name of the technical person who prepared the estimate for the above work.	Estimate of said work has been prepared on the basis of site requirement (as per bill of quantity) by Engineering Department.
02.	Whether estimate had been prepared as per actual site requirement after visiting site.	
03.	Certified copies of working drawings which were involved in preparing estimate and working out the quantities of all the items taken in LOA.	Since working drawing is POWERGRID's technical documents, the same can't be shared as per clause 8(1)(d) of RTI Act, 2005.
04.	Departmental Civil Engineer who were available during concreting work of spare foundation on 19.10.2019, whether he determined work ability test to know the water cement ratio with the help of slump cone apparatus which was available at site.	In order to ascertain water cement ratio, work ability test with the help of slump cone apparatus was carried out at site on 19.10.2019 and jointly verified by representatives of POWERGRID and agency.

Address of First Appellate Authority:

Sh. Sanjai Gupta
Executive Director, Northern Region – III
Power Grid Corporation of India Limited
12, Rana Pratap Marg, Lucknow – 226 001 (U.P.)
Tel: 0522 – 2205100

Thanking you,

Yours Sincerely,

(Kailash Kumar Gupta)

Sr. GM (PESM) & Designated CPIO, NR-III
POWERGRID, Lucknow