

Registered Post- Acknowledgement Due

Ref: SR-II: RTI: F-1142(IPO):2020/ 2821

Date: 6th November, 2020

To

Shri M.S.Gnana Janardhan, Adv.,
T20, No.10 Shopping Mall-3rd Floor,
Coimbatore Main Road,
Pollachi 642 002.

Tamil Nadu

Sub: Your RTI application - reg

Sir,

This has reference to your application dated 24/09/2020 under RTI Act, 2005 which had been returned to you vide our letter dated 30.09.2020 for valid RTI fee, is received at this office from our Palladam TLC on 20/10/2020. The query wise information sought in the application is furnished below:

1. The stone quarry/crusher to be operated only outside a minimum distance of 300 meters, so that the operation of the quarry does not affect the operation of the transmission line.
- 2&3. The foundation and the transmission line tower parts will be affected by such vibrations, and may result in failure of components leading to tripping of the transmission line on fault, and unwarranted outage of the power line.

As per section 19 of the Right to Information Act 2005, if required, you may file an appeal to the First Appellate Authority of the organisation within 30 days of the issue of this order. The address of the First Appellate Authority is given below:

Shri S.Ravi,
Executive Director (SRTS-II)
Power Grid Corporation of India Ltd.,
Singanayakanahalli, Yelahanka Hobli,
Bangalore 560 064.
e-mail : sr2edo@powergrid.co.in
Tel.No.: 080-23093701

Thanking you,

Yours faithfully,



(V.RAJESH)

Sr.General Manager & CPIO
e-mail id: sr2cpio@powergrid.co.in
Tel.No.: 080-23093711

Copy to: ED(SRTS-II), Appellate Authority, POWERGRID, SRTS-II, Bangalore - for kind information.