



पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड
Power Grid Corporation of India Limited
सूचना का अधिकार अभिनियम 2005 के अंतर्गत केन्द्रीय लोक सूचना अधिकारी
Central Public Information Officer under the RTI Act, 2005
केन्द्रीय कार्यालय, 'सौदामिनी', प्लॉट नं.2, सेक्टर-29, गुडगांव, हरियाणा-122007
Corporate Centre, 'Saudamini', Plot No. 2, Sector-29, Gurgaon, Haryana-122007



PGCIL/R/E/21/00029

दिनांक: 16 February, 2021

SHRI ARUN,
H.NO- 70, KAKROLA, TARANAGAR, DWARKA, Pin-110078
Delhi

विषय: सूचना का अधिकार अधिनियम, 2005 के तहत जानकारी।

महोदय / महोदया,

कृपया आर.टी.आई. अधिनियम, 2005 के तहत दिनांक 18 January, 2021 को प्रेषित अपने आर.टी.आई. अनुरोध का संदर्भ लें।


उपरोक्त पत्र में वांछित जानकारी अनुलग्नक-1 में संलग्न है।

यदि आप केन्द्रीय लोक सूचना अधिकारी के उत्तर से संतुष्ट न हों तो, केन्द्रीय लोक सूचना अधिकारी के उत्तर की प्राप्ति के 30 दिनों के भीतर पहले अपील प्राधिकारी के सम्मुख अपील की जा सकती है। आरटीआई अधिनियम, 2005 के तहत केन्द्रीय कार्यालय, गुडगांव में अपील प्राधिकारी का विवरण निम्नानुसार है:

श्री बी.एन.डे.भौमिक,
कार्यपालक निदेशक (तकनीकी विकास) एवं अपील प्राधिकारी
केन्द्रीय कार्यालय, पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड,
सौदामिनी, प्लॉट नंबर-2, सेक्टर-29, गुडगांव-122001, हरियाणा।
ईमेल आईडी: appellate.cc@powergrid.co.in
फोन नंबर: 0124-2571790,2863616

धन्यवाद,

भवदीय,


(जसबीर सिंह) 16/02/21

मुख्य महाप्रबंधक (के. आ.) एवं के.तो.सू.अधिकारी

Email ID: cpio.cc@powergrid.co.in

Sub.: Reply to RTI Query by Shri Arun, Delhi.

Query (1). Authorised Officer/Official for availing shutdown/Permit on 66kV overhead lines and underground cable in PGCIL?

Reply (1). As per norms the respective Maintenance Service Hub Engineer/Junior Engineer looking after the 66kV overhead lines/underground cable of PGCIL is authorized for availing shutdown/permit upon approval.

Query (2). Authorised Officer/Official for availing shutdown/Permit on 132kV overhead lines and underground cable in PGCIL?

Reply (2). As per norms the respective Maintenance Service Hub Engineer/Junior Engineer looking after the 132kV overhead lines/underground cable of PGCIL is authorized for availing shutdown/permit upon approval.

Query (3). Authorised Officer/Official for availing shutdown/Permit on 220kV overhead lines and underground cable in PGCIL?

Reply (3). As per norms the respective Maintenance Service Hub Engineer/Junior Engineer looking after the 220kV overhead lines/underground cable of PGCIL is authorized for availing shutdown/permit upon approval.

Query (4). Authorised Officer/Official for availing shutdown/Permit on 400kV overhead lines and underground cable in PGCIL?

Reply (4). As per norms the respective Maintenance Service Hub Engineer/Junior Engineer looking after the 400kV overhead lines/underground cable of PGCIL is authorized for availing shutdown/permit upon approval.

Query (5). Authorised Officer/Official for availing shutdown/Permit on transformer as per MVA capacity in PGCIL?

Reply (5). As per norms the respective Maintenance Service Hub Engineer/Junior Engineer looking after the transformer of PGCIL is authorized for availing shutdown/permit upon approval.

Query (6). According to above mentioned voltage level i.e., 66kV, 220kV, 400kV is there any hierarchy designation wise (i.e., Foreman, technical officer, J.E., A.E./ A.M., Manager/ Xen, DGM, GM., Sr. DGM) to be followed while availing PTW/Shutdown in PGCIL?

Reply (6). For availing PTW/Shutdown for voltage level i.e., 66kV, 220kV, 400kV, the respective Maintenance Service Hub Engineer/Junior Engineer is authorized for availing PTW/Shutdown after approval of concerned Maintenance Service Hub In-Charge.