

**Registered Post with Acknowledgement Due**

Ref: SR-II: RTI:F-1289:21-22/3235

Date: 17<sup>th</sup> November, 2021

Shri Saravanan,  
190, Vaathiyar Veedu,  
Ayyagoundenpalayam,  
Elumathur Post, ERODE-638 104.  
(Tamil Nadu)

Sir,

**Sub: Information sought under RTI Act, 2005 – reg.**

This has reference to your application dated 12/10/2021 under RTI Act, 2005 received at the office on 01/11/2021. The information sought in the application is furnished below:

Q.No.1 to 4: The land compensation valuation for the Sy.No.152/6 is yet to be assessed by the Revenue Department/RDO-Erode.


Q.No.5: As per Indian Electricity Act, the right of way width of  $\pm 800$  KV HVDC Transmission is 69 Meter (i.e. 34.5 Meter from the centre of the line). Plantation of tall growing trees under the right of way transmission line is not allowed. The permissible distance for plantation coconut trees from the centre of Transmission line is 34.5 Meter.

As per section 19 of the Right to Information Act 2005, if required, you may file an appeal to the First Appellate Authority of the organisation within 30 days of the issue of this order. The address of the First Appellate Authority is given below:

Shri S.Ravi, Executive Director (SRTS-II)  
Power Grid Corporation of India Ltd.,  
Singanayakanahalli, Yelahanka Hobli,  
Bangalore 560 064.  
e-mail : [sr2edo@powergrid.co.in](mailto:sr2edo@powergrid.co.in) Tel.No.: 080-23093701

Thanking you,

Yours faithfully,

  
(K.V.SATYANARAYANA)  
General Manager & CPIO  
e-mail id: [sr2cpio@powergrid.co.in](mailto:sr2cpio@powergrid.co.in)  
Tel.No.: 080-23093711

Copy to: ED(SRTS-II), Appellate Authority, POWERGRID, SRTS-II, Bangalore - for kind information