

Registered Post with Acknowledgement Due

Ref: SR-II: RTI:F-1297:21-22 / 3239

Date: 17th November, 2021

Shri M.K.Shoby,
Mullamkuzhy (H),
P.O.Puthur - 680 014
Thrissur
(Kerala)

Sir,

Sub: Information sought under RTI Act, 2005 – reg.

This has reference to your application dated 02/11/2021 under RTI Act, 2005 received at the office from our Kochi sub-station on 17/11/2021 (to-day). The information sought in the application is furnished below:


Q.No.1 & 2: As per Central Electricity Authority (Measures relating to Safety & Electric Supply) Regulations 2010, no building shall be constructed under an existing overhead line – Clause 60 (1) & 61(1). Further, POWERGRID is not the authority for issue the permission / deviations of CEA Regulations.

As per section 19 of the Right to Information Act 2005, if required, you may file an appeal to the First Appellate Authority of the organisation within 30 days of the issue of this order. The address of the First Appellate Authority is given below:

Shri S.Ravi, Executive Director (SRTS-II)
Power Grid Corporation of India Ltd.,
Singanayakanahalli, Yelahanka Hobli,
Bangalore 560 064.
e-mail : sr2edo@powergrid.co.in
Tel.No.: 080-23093701

Thanking you,

Yours faithfully,



(K.V.SATYANARAYANA)
General Manager & CPIO
e-mail id: sr2cpio@powergrid.co.in
Tel.No.: 080-23093711

Copy to: ED(SRTS-II), Appellate Authority, POWERGRID, SRTS-II, Bangalore - for kind information