



पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड
Power Grid Corporation of India Limited
सूचना का अधिकार अभिनियम 2005 के अंतर्गत केन्द्रीय लोक सूचना अधिकारी
Central Public Information Officer under the RTI Act, 2005
केन्द्रीय कार्यालय, 'सौदामिनी', प्लॉट नं.2, सेक्टर-29, गुडगांव, हरियाणा-122001
Corporate Centre, 'Saudamini', Plot No. 2, Sector-29, Gurgaon, Haryana-122001
CIN : L40101DL1989GOI038121



दिनांक: 8 August, 2023

PGCIL/R/E/23/00258

Johnny MA,
mechery house , koodapuzha , chalakudy, kerala, -680307 Kerala

विषय: सूचना का अधिकार अधिनियम, 2005 के तहत जानकारी ।

महोदय / महोदया,

कृपया आर.टी.आई. अधिनियम, 2005 के तहत दिनांक 12 July, 2023 को प्राप्त अपने आर.टी.आई. अनुरोध का संदर्भ लें ।

उपरोक्त पत्र में वांछित जानकारी अनुलग्नक-1 में संलग्न है ।

यदि आप केंद्रीय लोक सूचना अधिकारी के उत्तर से संतुष्ट न हों तो, केंद्रीय लोक सूचना अधिकारी के उत्तर की प्राप्ति के 30 दिनों के भीतर पहले अपील प्राधिकारी के सम्मुख अपील की जा सकती है। आर.टी.आई अधिनियम, 2005 के तहत केंद्रीय कार्यालय, गुडगांव में अपील प्राधिकारी का विवरण निम्नानुसार है:

श्री बी.अनंत शर्मा

कार्यपालक निदेशक (केंद्रीय आयोजना एवं सी. एस.) एवं अपील प्राधिकारी

केंद्रीय कार्यालय, पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड,

सौदामिनी, प्लॉट नंबर-2, सेक्टर-29, गुडगांव-122001, हरियाणा।

ईमेल आईडी: appellate.cc@powergrid.co.in

फोन नंबर: 0124-2571994

धन्यवाद,

भवदीय,

() . जगन्नाथ राव
08/08/23

(ए. जगन्नाथ राव)

मुख्य महाप्रबंधक (केंद्रीय आयोजना) एवं
केंद्रीय लोक सूचना अधिकारी

Email ID: cpio.cc@powergrid.co.in

**Sub: Reply to RTI Request of Sh. Johnny MA, Chalakudy, Kerala
(RTI Regn. No. PGCIL/R/E/23/00258)**

Sl. No.	Information sought:	Reply:
1.	Are there any guidelines and exposure limits for EMFs from electricity tower lines	Yes, guidelines on EMF for transmission lines are available in Central Electricity Authority (CEA) (Measures relating to safety and electric supply) regulations 2023.
2.	Are there any guidelines for measuring EMF readings from electricity tower lines. Are there any local authorities or relevant organizations responsible for monitoring and regulating EMF levels in Kerala. If so, could you provide their contact details.	No guidelines. Procedure for measuring EMF is readily available in IEEE644 standard for transmission lines. Kerala State Electricity Board may be contacted for the information related to authority for the state of Kerala.
3.	Are there any safe distance guidelines or limits for exposure to EMFs from tower lines	Same as (1) above.

आकाश
08/08/2023