

पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड

(भारत सरकार का उद्यम)

पूर्वी क्षेत्र पारेषण प्रणाली-1, मुख्यालय,
बिहार राज्य ईलेक्ट्रिसिटी बोर्ड कोलोनी,
टी. आर. डब्लू भवन के नजदीक,
पोस्ट+थाना - शास्तीनगर, पटना- 800023

संदर्भ: पावरग्रिड/पू.क्षे.-1 क्षे.मु./आर.टी.आई-374/2024-25/

दिनांक: 20.06.2024

सेवा में,

श्री ब्रज मोहन कुमार

ग्राम - बिजावन पर

पोस्ट - महानंदपुर, थाना - दीपनगर

जिला - नालंदा (बिहार) पीन - 803216

विषय : Information sought under RTI Act,2002.

Ref. : RTI registration no. PGCIL/R/E/24/275 dtd.20.05.2024

Sir,

Please find the information as below against your RTI registration No. PGCIL/R/E/24/275 dtd.20.05.2024.

Due to widening/ construction of NH-31, realignment of some towers was required. As per technical feasibility & to minimise the damage and to utilize the existing towers / corridors, all the new towers have been spotted just below the existing corridor. Some overhead conductors are passing over the nearby open land and there is more than 46 meters vertical clearance of the aforesaid Transmission lines corridors.

The realignment of required towers was done after following the all rules and regulations relating to transmission of electricity which are available in public domain.

This is for your kind information please.

भवदीय

20/06/24

(माज़ आलम)

उप महाप्रबंधक, बिहारसरीफ सह

डीमंड लोक सूचना अधिकारी