

FORM-A

Form of application for seeking application  
According to U/S 5 & Rule 3 of Right to Information Act-2001

RTI 93

Pls process  
urgent-17  
30/11  
17/11

To, DGM (PE&M) & CPIO NER Loweroid Shillong

1. Name of the Applicant: Abdur Rahman Barbhuiya

2. Father's Name Address: 2/0 Lt Mossaddar Lt Barbhuiya  
Nil - Nischintapur Pt - I P.O. Nischintapur  
P. S. Dist. Hailakandi Assam. 788164

3. Telephone No.: (M) ..... 4. Email Address: .....

5. (A) Concerned Department: Power grid Corporation of India.

(B) Detail of Information required:

- ① How many meters are declared as affected area from Loc?
- ② How far away from Loc or power line plantation/ construction make? as per power line guide line.
- ③ Whether each affected areas whose lands situate within affected area entitle to compensate irrespective of quantum of value of property? whether seeking compensation as per law is illegal?

(C) Period for which the information ask for: .....

(D) Other details: all the above information/documents are illegal.

6. I, state that the information sought does not fall within the restrictions contained in section of the Act and rules to the Act and to the best of my knowledge, it pertains to your office..

7. A fee of Rs. 10 (Ten) has been deposited vide memo No. 140. 859/00.

Date: 2. 04. 2014

Place Hailakandi

Abdur Rahman Barbhuiya

Signature of the Applicant.

ACKNOWLEDGEMENT OF APPLICATION IN FORM

I.D. No.....

Date: .....

1. Receive an application in form-A from..... Resident of..... U/S 5 Assam Right To Information Act 2001.
2. The information is proposed to be given normally within 15 days and if any case within 30 days from the demand of receipt of application and in case it is found that the information asked for cannot be supplied, the rejection letter shall be issued stating the reason thereof.
3. The applicant is advised to contact the undersigned on between 11 to 1 P.M.
4. In case the applicant fails to turn up the schedule dates. The in-charge of office shall not be responsible for delay if any.
5. The applicant shall have to deposit the balance fee if any to the Authorized person before collection of the information.
6. The applicant may also consult website of the department from time to time to ascertain the status of the application.

11/11/14





REGD A/D ONLY

संदर्भ संख्या/Ref No: NESH/PESM/RTI/1117/ 64

दिनांक/Date: 16/5/15

To:

Abdur Rahman Barbhuiya,  
S/o Lt. Mosaddar Ali Barbhuiya  
Vill. Nischintapur-I, P.O. Nischintapur,  
P.S. & Dist. Hailakandi, Assam-788164.

Sub: Reply to your RTI Query vide application No. 93, dated 02.04.2014, received on 11.04.2014.

Sir,

- 1.0 This is in reference to your application dated 02.04.2014 under RTI Act 2005, received on 11.04.2014. From our data base, reply to your query is appeared to have not been replied. We are therefore sending pointwise reply to the same.
- 2.0 There is no fixed area which is declared as affected from any location of a transmission line. However, the portion of land where surface damages are incurred during the construction of a tower is considered as affected area.
- 3.0 As per rule 80 of IE Rule 1956, Where a high or extra-high voltage overhead line passes above or adjacent to any building or part of a building it shall have on the basis of maximum sag :
- o/c
- i) vertical clearance above the highest part of the building immediately under such line, of not less than-
- (a) for high voltage lines upto and including 33,000 volts : 3.7 metres  
(b) for extra-high voltage lines : 3.7 metres plus 0.30 metre for every additional 33,000 volts or part thereof.
- (ii) The horizontal clearance between the nearest conductor and any part of such building shall, on the basis of maximum deflection due to wind pressure, be not less than-
- (a) for high voltage lines upto and including 11,000 volts : 1.2 metres  
(b) for high voltage lines above 11,000 volts and up to and including 33,000 volts : 2.0 metres  
(c) for extra-high voltage lines : 2.0 metres plus 0.3 metre for every additional 33,000 volts for part thereof.

Similarly, for plantation adequate electrical clearance from the lowermost conductor as per IE Rule 1956 have to be ensured.

3.0 Compensation towards crop/tree/hut affected during the construction of transmission line is considered as per approved rates of concerned State Government authorities in line with the provisions of Indian Telegraph Act'1885 and Indian Electricity Act'2003.

4.0 Kindly acknowledge receipt of this letter.

Thanking you,

Copy (NOI): 1. DGM (Vig.), Shillong.

Yours faithfully

डा. प्रदीप  
16/5/15

DGM (PESM) & CPIO  
POWERGRID, Shillong.