

FORM A

FORM OF APPLICATION FOR SEEKING INFORMATION UNDER
THE RIGHT TO INFORMATION ACT '2005'

1. The A.G.M (Const), Gausahati Camp, Tezpur
Near Collegiate High School, Margaon Baruah chuburi,
P.O - Tezpur - 784001 (Assam)
2. The A.G.M, Power Grid Corporation of India Ltd.
Chariduar, Balipara, Dist - Sonitpur (Assam)
P.O - Balipara, Pin - 784103.

From

1. Name of the Applicant : MD JAYNAL ABDIN, S/O - MD AHMED ALI, VILL & P.O KHALIHAMAR
2. Address : P.S - TEZPUR, PIN - 784026, DIST - SONITPUR (ASSAM)
P.S - Khalihamar
3. Telephone no. : 7896272939

4. Email Address : (1) What is the specific distance between 2 (two) towers
as per your Rule.

5. Particulars of Information : (2) what is the specific distance of wire level
between land level to wire level.

Your reply will be come within the stipulated time
30 days, otherwise I shall go to Appeal and legal suit.

6. Preferred language of the said information is, ENGLISH

7. I state that the information sought for does not fall within the restriction contained in section 4 of the Act and to the best of my knowledge it pertains directly to you office.

8. I state that the information may be sent per post and for this purpose a self addressed stamped envelop is annexed.

9. A fee of Rs. 10/- is deposited by Joyal Abdin
(P.O No. 82 G Dt. 18/7/16 at Tezpur Head-Post Office, Sonitpur ASSAM.)

048356

Date - 18/07/2016

Md. Joyal Abdin

Signature of the Applicant

S/O - Md Ahmed Ali
Vill & P.O - ~~Khalihamar~~ Khalihamar
P.S - Tezpur, PIN - 784026
Dist - Sonitpur (Assam)

POWER GRID CORPORATION OF INDIA LIMITED
(A Government of India Enterprise)

डोंगटिह, लोवर नोंग्राह, लापालांग, शिलांग दृ 7793006 (मेघालय)
दूरभाष: 0364-2536562, फैक्स: 2536387

Dongtiah, Lower Nongrah, Lapalang, Shillong – 793006 (Meghalaya)

Telephone: (0364) 2536562, Fax: 2536387

उत्तर पूर्वी क्षेत्र पारेशन प्रणाली / NORTH EASTERN REGION TRANSMISSION
SYSTEM

SPEED POST

Ref No: NESH/PESM/RTI-291/ 131

Date: 29.07.2016

To:

Sri Jaynal Abdin
S/O Amod Ali
Vill. & P.O.- Khalihamari,
P.S.- Tezpur, Dist.- Sonitpur,
Assam, Pin – 784026

Sub: Your application dtd.18.07.2016

Sir,

- 1.0 This is in reference to your application dated 18.07.2016, received at CPIO office at Shillong on 28.07.2016.
- 2.0 Your query is not specific to any transmission line. However, POWERGRID in general engaged for construction and maintenance of 132KV and above voltages transmission lines. So, information with respect to these transmission are furnished below:-

Reply to query-01

The average ruling span between two towers for EHV Line is given below-

132 KV and 220 KV - 350 Metre

400 KV, 765 KV & 800KV HVDC - 400 Metre.

However, depending upon Terrain, Wind Zone, Conductor type etc. the average ruling span may vary.

Reply to query-02

The permissible minimum ground clearances of EHV Lines (for POWERGRID) are given below:

LINE VOLTAGE IN (KV)	GROUND CLEARANCE
110/132	6.1 Metre
220	7.015 Metre
400	8.840 Metre
765	15.00 Metre
±500 HVDC	12.50 Metre
±800 HVDC	18 Metre for rural & 20 Metre for urban area.

- 3.0 The address of the appellate authority is mentioned hereunder for your information:

Sh. A Choudhary, ED (NERTS)
POWERGRID, Dongtiah, Lower Nongrah,
Lapalang, Shillong - 793006, Meghalaya.
0364-2536371, abhaychy@gmail.com
Kindly acknowledge receipt of this letter.

भवदीय,

Re
01.08.16

उप महाप्रबंधक

(के. लो. सू. अधिकारी)

0364-2536439,

cpio.nerts@gmail.com

Copy to:

The State Public Information Officer & Asstt. Commissioner, Tezpur for kind information please. This has a reference to letter No: SRTI-2/2016/1275 Dated 19/07/2016.

NIO- Manager(Vig), Shillong

AGM, Bahipara / CM, Tezpur