

ACTION HISTORY OF RTI REQUEST No.PGCIL/R/E/22/00149

Applicant Name ABHINAV NAIN

Text of Application

Dear sir Indian Oil Corporation petrol pump is proposed at Khasra No. 1224A and 1224B, Moja Village, Naithala Bangar Tehsil and District Baghpat NH709B. For which no objection certificate has been issued from the Electricity Department (Electricity Distribution Division, Baghpat, Uttar Pradesh). Sir, you have to inform that 400KV line is passing from both the sides of above khasra number due to which the distance of proposed plot is less than 15 meters. Sir, please give your answer on the following points. 1. At what distance should the 400KV line be from the petrol pump. 2. Whether NOC has been obtained from PGCIL Mataur Meerut also. 3. If the distance of the proposed plot as per rules is less than the 400 KV line passing through, then on what basis no objection certificate has been issued. Also refer to allahabad high court order under Writ No. 1869 of 2015 PGCIL v/s district migestriate prayagraj

Reply of Application

Point-wise information: Information to Point No.1: 400kV S/C line corridor (ROW) is 26 Meter either side from center of Tower. Information to Point No.2 & 3 : Matter pertains to Civil Administration, information may be sought from appropriate authority.

SN.	Action Taken	Date of Action	Action Taken By	Remarks
1	RTI REQUEST RECEIVED	19/04/2022	Nodal Officer	
2	REQUEST FORWARDED TO CPIO	20/04/2022	Nodal Officer	Forwarded to CPIO(s) : (1) Rajesh V (NR-I)
3	REQUEST DISPOSED OF	25/04/2022	Rajesh V (NR-I)-(CPIO)	

[Print](#)