

Registered Post with Acknowledgement Due

Ref: SR-II/RTI/F-249/2014 / 31632

Dt: 23.07.2014

To

Shri.S Suresh,  
S/o Siddangatah,  
Appahna Palya, Obalapura Post,  
Tumkur-taluk & Dist  
Karnataka-PIN 678507


Sub: Information under RTI Act 2005-reg:

Sir,

This has reference to your RTI application received in this office on 03.07.2014 through our Tumkur TLC Office. Reply to your query is enclosed here with as Annexure.

Thanking You

Encl: As above

Yours faithfully,  
  
(Sunil K. Thomas)  
DGM & CPJO

Copy to-ED/SRTS- II, Appellate Authority, POWERGRID,SR-II--for kind information please

~~SC~~

Annexure

Point wise reply to the queries under RTI act 2005 by Shri S Suresh, Appaiana Palaya-Tumkur Village

SI No	Query	Reply from POWERGRID
1	What is the kv capacity which passes through Chikkatholakere to Appaiahna Palaya	400 kv
2	Is your company obtained permission from the forest Department	No. This project has no forest crossing.
3	Is your company obtained permission letter from the pollution control board	No. This is a non-polluting project.
4	As per the guidelines how many metres requires i.e. Maximum and Minimum metres?	<p>The required clearance is as per Central Electricity Authority (Measures relating to safety &amp; Electric Supply) Regulation, 2010.</p> <p>Section 58 stipulates the clearance from ground.</p> <p>Section 61 stipulates the clearance from buildings.</p>

*Suresh*