

प.क्षे.-II/लोक सूचना/2021/00526

दिनांक : 04/01/2021

सेवा में,
श्री हेमांश
G-203, Shripad Antalia,
Pal Adajan, Surat – 395 009, Gujarat.

विषय : सूचना का अधिकार अधिनियम 2005 के अंतर्गत मांगी गयी जानकारी के संबंध में ।


महोदय,

सूचना के अधिकार अधिनियम 2005 के तहत आपके द्वारा प्रेषित पत्र, इस कार्यालय में के.लो.सू. के द्वारा दिनांक 10/12/2020 को प्राप्त हुआ है। आवेदन पत्र में मांगी गयी जानकारी इस पत्र के साथ संलग्न प्रेषित है।

यदि आप केंद्रीय लोक सूचना अधिकारी के उत्तर से संतुष्ट न हों तो, CPIO के उत्तर की प्राप्ति के 30 दिनों के भीतर अपीलिय अधिकारी के सम्मुख अपील कर सकते हैं। आरटीआई अधिनियम, 2005 के तहत अपीलिय अधिकारी का नाम और पता निम्नानुसार है।

श्री शंकर दत्त जोशी, अपीलिय अधिकारी,
पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड,
प्लॉट नं.-54, अम्बे विद्यालय के सामने, समा-सावली रोड,
वडोदरा – 390 024 (गुजरात).

धन्यवाद सहित,


4/1/2021
केन्द्रीय लोक सूचना अधिकारी
पश्चिम क्षेत्र – II, वडोदरा

संलग्न : यथोपारि

प्रतिलिपि: -

1. कार्यपालक निदेशक (प.क्षे.-II), वडोदरा – सादर सूचनार्थ
2. महाप्रबंधक (सतर्कता), प.क्षे.- II

RTI Request Reply

Registration No: PGCIL/R/E/20/00526

Date: 10/12/2020

(a) 220kV D/C Kawas-Vav Transmission Line Shifting Work at Abrama Village dist surat.

Tower location no. 89/0 DD+9

Tower location no. 89/A DD+9

Tower location no. 90/0 DD+6

1. No such technical requirement in transmission line Tower.

2. Nominal insulator length at all above towers is 2175 mm



PPS Thakur
Chief Manager (Powergrid)
Navsari GIS S/s, Surat