

प.क्षे.-II/ लोक सूचना/2023-24/00143/ 33

दिनांक : 13.04.2024

सेवा में,
श्री रमेश श्रीवास्तव,
730 अग्रवाल कालोनी जैन मंदिर के पास,
जबलपुर, जिला- जबलपुर (म.प्र.)
पिन कोड-482002,
मोबाइल नंबर-9300650955

विषय : सूचना का अधिकार अधिनियम 2005 के अंतर्गत मांगी गयी जानकारी के संबंध में।

महोदय,

सूचना का अधिकार अधिनियम 2005 के तहत आपके द्वारा दिनांक 12/03/2024 को प्रेषित पत्र ऑनलाइन के माध्यम से पावरग्रिड क्षेत्रीय मुख्यालय में दिनांक 15/03/2024 को प्राप्त हुआ है। आवेदन पत्र में मांगी गयी जानकारी से संबंधित जवाब इस पत्र के साथ संलग्न कर प्रेषित की जा रही है।

यदि आप केंद्रीय लोक सूचना अधिकारी के उत्तर से संतुष्ट न हों तो, CPIO के उत्तर की प्राप्ति के 30 दिनों के भीतर अपीलिय अधिकारी के सम्मुख अपील कर सकते हैं। आरटीआई अधिनियम, 2005 के तहत अपीलिय अधिकारी का नाम और पता निम्नानुसार है:-

श्री कृष्ण कुमार टी. आर. (कार्यपालक निदेशक), अपीलिय अधिकारी,
पावर ग्रिड कॉर्पोरेशन आफ इंडिया लिमिटेड,
क्षेत्रीय मुख्यालय, पश्चिम क्षेत्र-2
प्लॉट नं.-54, रिया-रेवती रिसोर्ट के पास, समा-सावली रोड,
वडोदरा – 390008 (गुजरात).

धन्यवाद सहित,

f/o अक्षय
13.04.24
(पंकज दलाल)
केन्द्रीय लोक सूचना अधिकारी
पश्चिम क्षेत्र – II, वडोदरा

संलग्न: - यथोपरि,

प्रतिलिपि: -

1. कार्यपालक निदेशक (प.क्षे.-II), वडोदरा – सादर सूचनार्थ
2. मुख्य प्रबंधक (सतर्कता), प.क्षे.-II
3. मुख्य प्रबन्धक (LAW), प.क्षे.-II

क्षेत्रीय मुख्यालय प्लॉट सं.54, रिया रेवती रिसोर्ट के पास, अम्बे विद्यालय के सामने समां सावली रोड, वडोदरा-390008(गुजरात)

RHQ/ Plot No.54, Adjacent to Riya-Revati Resort, Opp Ambe Vidhyalaya, Sama Savli Road Vadodara – 390008(Gujarat)

केन्द्रीय कार्यालय: "सौदामिनी", प्लॉट नंबर 2, सेक्टर-29, गुरुग्राम -122001, (हरियाणा) दूरभाष: 0124-2571700-719

Corporate Office: "Saudamini", Plot No. 2, Sector-29, Gurugram-122001, (Haryana) Tel.: 0124-2571700-719

पंजीकृत कार्यालय: बी -9, कुतब इंस्टीट्यूशनल एरिया, कटवारिया सराय, नई दिल्ली -110 016. दूरभाष: 011-26560112, 26560121, 26564812, 26564892, CIN: L40101DL1989GOI038121

Registered Office: B-9, Qutab Institutional Area, Katwaria Sarai, New Delhi-110 016. Tel: 011-26560112, 26560121, 26564812, 26564892, CIN : L40101DL1989GOI038121

Website: www.powergridindia.com

आपके द्वारा दिनांक 12/03/2024 को प्रेषित पत्र (आरटीआई संख्या PGCIL/WRTS-II/2023-24/143) से संबंधित चाही गयी जानकारी का उत्तर इस प्रकार है:-

| क्र. | आरटीआई अर्जी | आरटीआई का उत्तर |
|------|---|--|
| 1 | Compensation details for property of Boring and Pump House constructed on area of 12 x 15 Sq feet = 300 Sq. Feet, situated at PH no 67 Khasra No 343/2, 381/1 and 387/2, At & Post Gundrai, Dist- Narsinghpur Pin-487118 (hereinafter referred to as the "property") below the high and extra high tension transmission line of 765kV double circuit, starting from NTPC Gadarwada to-Jabalpur pooling station over the said property | As per the record available at site compensation not paid for Pump House & Bore Well, situated at PH no 67 Khasra No 343/2, 381/1 and 387/2 at and post Gundrai, Dist- Narsinghpur Pin-487118 |
| 2 | Guideline for compensation in term of horizontal and vertical clearance, for a property situated below the high voltage line up to or including 33,000 volts. | POWERGRID maintains Horizontal & vertical clearance as per the clause No. 63 of CEA Regulation (Central Electricity Authority measures related to safety and electric supply) However, POWERGRID is paying the compensation for loss or damages, if any, of the standing trees/crops/property to the land owners at the time of construction activities along with the compensation towards the diminishing value on the basis of the assessment issued by the concerned State Government, District Collector and Revenue Department on the basis of Section 86 and 164 of the Electricity Act and Part 111 of the Indian Telegraph Act-1885 and Electricity Rules 1956. |
| 3 | Guideline for compensation in term of horizontal and vertical clearance, for a property situated below the high voltage line up to or including 765,000 volts. | |
| 4 | Guideline for compensation in term of horizontal and vertical clearance, for a property situated below the high voltage line up to or including 796,000 volts. | |
| 5 | Acknowledgement and action taken reports by NTPC Jabalpur officials and or revenue authority of Gotegaon Tehsildar and SDM Narsinghpur in response to the applicant's letter dated 21.02.2019, 26.04.2019 and 06.12.2029 and afterwards. | No such document is available. |
| 6 | In connection to the above weather any reports, memos, visit details recommendation/non-recommendations, claims or were made by the competent authorities regarding compensation to the applicant with respect to the said Property. | As per the record available at site compensation not paid for Pump House & Bore Well, situated at PH no 67 Khasra No 343/2, 381/1 and 387/2 at and post Gundrai, Dist- Narsinghpur Pin-487118 |
| 7 | What is the safe distance / clearance vertical & Horizontal for constructed property from high tension electrical line for 765kV / 796kV extra high voltage lines since electric & magnetic field from high tension lines are classified as "Extremely Low Frequency (ELF) radiation which may cause human health issue like vertigo, nausea dizziness and headache fatigue and listlessness insomnia and long term exposure leads to cancer. | During the construction of transmission lines all precaution, safety measures and safe electrical clearance are taken as per CEA safety rules & regulations. Hence, any environment clearance not required for installation and operation of transmission line. |

H/O
Ambe
13.04.2024

(पंकज दलाल)
केन्द्रीय लोक सूचना अधिकारी
पश्चिम क्षेत्र - II, वडोदरा