

Gurnek Singh Brar

1, Ranjit Bagh, Opp. Modi Mandir
Patiala - 147 001

To

CPIO, WRLDC
Mumbai

No: GSB/WRLDC

Dated: 14/5/2014

Sub: RTI Application

It is requested that the following information may please be supplied under RTI Act 2005.

Description

The information requested for relates to the Energy Generation and Auxiliary consumption at Sasan UMPP.

INFORMATION REQUESTED TO BE SUPPLIED

1. Please supply the energy figures in MWh as recorded by the following SEM meters for the period 16/4/2014 upto 15/5/2014.

| Location ID | Description |
|-------------|-------------------|
| SA-03 | 765 kV side, GT-3 |
| SA-02 | 765 kV side, GT-2 |
| SA-04 | 765 kV side, GT-4 |
| SA-15 | 400 kV side, ST-1 |
| SA-16 | 400 kV side, ST-2 |

2. Please inform the present status of installation of following SEM meters

- 765 kV side of GT, unit 5
- 765 kV side of GT, unit 6

2.1 In case these SEM meters have been installed the location ID, sr. no., CTR, PTR may be informed.

| |
|---|
| पोसोको / POSOCO प.वे.भा.पे.के. / WRLDC आ.क्रं. / I.W. NO. |
| 1009 16 MAY 2014 |
| प्राप्त किया / RECEIVED मुंबई / MUMBAI |

Sachdev

16/5/14

3. Please inform the commissioning status of the following equipment of 765 kV substation at Sasan as per record of WRLDC (status as on 15/5/2014)

- a) 765 kV, 240 MVAR bus reactor
- d) 765 kV, 240 MVAR line reactor, Sasan Satna circuit 2 at Sasan end.


4. Please inform the Tap position of the following transformers at Sasan (as on 15- 5-2014)

- a) Generator transformer unit 3, GT-3
 - b) Generator transformer unit 2, GT-2
 - c) Generator transformer unit 4, GT-4
- RTI fee of Rs 10/- is enclosed.


Gurnek Singh Brar


INDIAN POSTAL ORDER

INDIAN POSTAL ORDER



PAY TO Rosoco Mumbai

THE SUM OF RUPEES TEN ONLY




AT THE POST OFFICE AT Mumbai

Mumbai

THE ORDER IS VALID UNTIL THE DATE OF MATURING BEYOND THIS LINE

23F 372416



WITH COMMISSION AT 50 PAISE

THE ORDER IS VALID UNTIL THE DATE OF MATURING BEYOND THIS LINE

ORDER MAY BE PAID BY THE NAME AND ADDRESS HEREIN
G S Bhan
1 Kavit Bazar
Patil

पावर सिस्टम ऑपरेशन कारपोरेशन लिमिटेड
(पावरग्रिड की पूर्ण स्वामित्व प्राप्त सहायक कंपनी)
POWER SYSTEM OPERATION CORPORATION LIMITED
(A wholly owned subsidiary of POWERGRID)



पश्चिम क्षेत्रीय भार प्रेषण केन्द्र

एफ-३, सेन्ट्रल रोड, एम्.आई.डी.सी. एरिया, मरोल, अन्धेरी (पूर्व), मुंबई-400 093.

दूरभाष (O) : 022-28202690, 28203885, 28397634 • ई-मेल : wrldc@bol.net.in • फैक्स : 022 28235434, 28202630

WESTERN REGIONAL LOAD DESPATCH CENTRE

F-3, MIDC Area, Marol, Andheri (East), Mumbai - 400 093.

Phone (O) : 022-28202690, 28203885, 28397634 • E-mail : wrldc@bol.net.in • Fax : 022 - 28235434, 28202630

संदर्भ संख्या / Ref. No.

Ref: WRLDC/SO-I/RTI/309/14/ 734

Date: 02.06.2014

TO

Gurnek Singh Brar,
1,Ranjit Bagh,Opposite Modi Mandir
Patiala,147001

Subject: Information sought under RTI Act, 2005.

Dear Sir,

This is in reference to your letter dated 14th May, 2014 received in this office on 16th May, 2014 regarding the information pertaining to SASAN UMPP. The point-wise reply of your query as provided by concerned department is as mentioned below:

Q1. Please supply the energy figures in MWh as recorded by the following SEM meters for the period 16/04/2014 upto 15/05/2014.

| Location ID | Description |
|-------------|-------------------|
| SA - 03 | 765 kV side,GT -3 |
| SA - 02 | 765 kV side,GT -2 |
| SA - 04 | 765 kV side,GT -4 |
| SA - 15 | 400 kV side,ST -1 |
| SA - 16 | 400 kV side,ST-2 |

Desired data is available in the following link.

<http://www.wrldc.com/RTI%20Response/Response%20to%20SASAN%20query2/>

Q2. Please inform the present status of installation of following SEM meters.

- 765 kV side of GT,unit 5
- 765 kV side of GT,unit 6

As the above units are not synchronised yet, the desired information is not available .

o/c

2.1 In case these SEM meters have been installed the location ID,sr.no CTR,PTR may be informed.

Information is not available.

Q3. Please inform the commissioning status of the following equipment of 765 kV substation at Sasan sa per record of WRLDC (status as on 15/5/2014)

- a)765kV,240 MVAR bus reactor
- b)765kV ,240 MVAR line reactor,Sasan –Satna ckt-2 at Sasan end .

- a) 240 MVAR Bus reactor – yet to be commissioned
- b) Not yet commissioned

Q4. Please inform the Tap position of the following transformers at Sasan(as on 15.05.2014)

- a)Generator transformer unit-3 ,GT-3
- b)Generator transformer unit-2 ,GT-2
- c)Generator transformer unit-4 ,GT-4

All Generator transformers of Sasan (GT #2,3 & 4) are at Tap position 4.

Q5. Please inform /supply copy of all fax/email messages from SPL or MPPMCL to WRLDC regarding the trial run of Sasan unit-4.

Desired messages are attached.

Q6. Please inform /supply copy of all fax/email messages from SPL or MPPMCL to WRLDC regarding COD of Sasan unit-4.

Desired messages are attached.

Thanking You.


(V K Shrivastava)

AGM & CPIO

CC: GM & AA, WRLDC, Mumbai: - for kind information please.